



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
271023-H003
Component
Unknown Component
Fluid
BP TURBINOL X (--- GAL)



DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

Contamination

{not applicable}

Fluid Condition

{not applicable}

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|----------|----------|
| Sample Number | Client Info | | WC | --- | --- |
| Sample Date | Client Info | | 27 Oct 2023 | --- | --- |
| Machine Age | hrs | Client Info | 0 | --- | --- |
| Oil Age | hrs | Client Info | 0 | --- | --- |
| Oil Changed | | Client Info | N/A | --- | --- |
| Sample Status | | | NORMAL | --- | --- |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | | NEG | --- | --- |

VISUAL

| | method | limit/base | current | history1 | history2 |
|--------------|--------|------------|--------------|----------|----------|
| White Metal | scalar | Visual* | NONE | --- | --- |
| Yellow Metal | scalar | Visual* | NONE | --- | --- |
| Precipitate | scalar | Visual* | NONE | --- | --- |
| Silt | scalar | Visual* | NONE | --- | --- |
| Debris | scalar | Visual* | NONE | --- | --- |
| Sand/Dirt | scalar | Visual* | NONE | --- | --- |
| Appearance | scalar | Visual* | NORML | --- | --- |
| Odor | scalar | Visual* | NORML | --- | --- |

FLUID PROPERTIES


| | method | limit/base | current | history1 | history2 |
|------------------------|---------|-------------|------------|----------|----------|
| Oxidation Test (RPVOT) | minutes | ASTM D2272* | 401 | --- | --- |

SAMPLE IMAGES


| | method | limit/base | current | history1 | history2 |
|--------|--------|------------|---|----------|----------|
| Color | | |  | no image | no image |
| Bottom | | |  | no image | no image |



OIL ANALYSIS REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC
Lab Number : 02593073
Unique Number : 5670152
Test Package : TEST (Additional Tests: RPVOT)

Alpha Maintenance Systems
 WearCheck Belgium, 713 Bergensesteenweg
 St.-Pieters-Leeuw, ZZ
 BE B-1600
 Contact: Bart Coen
 bart.coen@alphams.eu
 T:
 F: 3(202)361-3458

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.