



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	SEVERE
FLUID CONDITION	NORMAL

Machine Id  
**RADAR SITE MOTOR#1**  
 Component  
**Unknown Component**  
 Fluid  
**{not provided} (--- LTR)**

**RECOMMENDATION**

We advise that you check all areas where dirt can enter the system. We recommend either performing an oil change or oil filtration. We cannot recommend specific action as we have limited information with regards to reservoir capacity and/or lubricant type.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0038709	---	---
Sample Date		Client Info		29 Apr 2003	---	---
Machine Age	yrs	Client Info		0	---	---
Oil Age	yrs	Client Info		0	---	---
Filter Age	yrs	Client Info		0	---	---
Oil Changed		Client Info		N/A	---	---
Filter Changed		Client Info		N/A	---	---
Sample Status				SEVERE	---	---
Water		WC Method		NEG	---	---


**WEAR**

All component wear rates are normal.


▲ Silicon (ppm)




Ferrous Alloys




Acid Number




Non-ferrous Metals




Viscosity @ 40°C



Viscosity @ 40°C



Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0038709 **Received** : 05 May 2003  
**Lab Number** : 01023773 **Tested** : 06 May 2003  
**Unique Number** : 1513631 **Diagnosed** :  
**Test Package** : IND 2

**NAV CANADA**  
 280 HUNT CLUB ROAD  
 OTTAWA, ON  
 CA K1V 1C1  
 Contact: Francis Gravel  
 Radar@navcanada.ca  
 T: (613)299-9735  
 F: (613)248-7195

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.