Machine Id

15501191 - SSG #2

**Diesel Engine** 

PETRO CANADA DURON HP 15W40 (62 LTR)

## RECOMMENDATION

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the component make and model with your next sample.


				/		
Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0700700		
Sample Date		Client Info		30 Nov 2022		
Machine Age	hrs	Client Info		53448		
Oil Age	hrs	Client Info		509		
Filter Age	hrs	Client Info		509		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				NORMAL		
PQ		ASTM D8184*		0		
Iron	nnm	ΔSTM D5185(m)	<b>\100</b>	10		

## WEAR

All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.

Magn: 200	x Illum: BC			
			1	100,
	Si I	110		
		11.		
1		1		
				ASS





Machine Age	1113	Oliciti IIIIo		30770		
Oil Age	hrs	Client Info		509		
Filter Age	hrs	Client Info		509		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				NORMAL		
DO		A CTM D0104*				
PQ	10.100.100	ASTM D8184*	. 100	0		
Iron Chromium	ppm	ASTM D5185(m)	>100	10 0		
Nickel	ppm	ASTM D5185(m)	>20	0		
Titanium	ppm	ASTM D5185(m)	>4	-		
	ppm	ASTM D5185(m)	. 0	<1		
Silver	ppm	ASTM D5185(m)	>3	0		
Aluminum	ppm	ASTM D5185(m)	>20	<1		
Lead	ppm	ASTM D5185(m)	>40	2		
Copper	ppm	ASTM D5185(m)	>330	4		
Tin	ppm	ASTM D5185(m)	>15	<1		
Vanadium	ppm	ASTM D5185(m)		0		
Large Particles		DR-Ferr*		4.9		
Small Particles		DR-Ferr*		3.6		
Total Particles		DR-Ferr*	>	8.5		
Large Particles Percentage	%	DR-Ferr*		15.3		
Severity Index		DR-Ferr*		6		
Ferrous Rubbing	Scale 0-10	ASTM D7684*		2		
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		1		
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*				
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
					1	

## **CONTAMINANTS** Silicon ASTM D5185(m) >25 3 ppm There is no indication of any contamination in the oil. Potassium ASTM D5185(m) >20 0 ppm Fuel WC Method >5 <1.0 Water WC Method >0.2 NEG NEG Glycol WC Method Soot % % ASTM D7844\* >3 Nitration Abs/cm ASTM D7624\* >20 8.7 Sulfation Abs/.1mm ASTM D7415\* >30 22.5 **Emulsified Water** scalar Visual\* >0.2 NEG ASTM D7684\* Carbonaceous Material Scale 0-10 Sand/Dirt Scale 0-10 ASTM D7684\* 1 Fibres ASTM D7684\* Scale 0-10 **Spheres** Scale 0-10 ASTM D7684\* Other ASTM D7684\* 1 Scale 0-10 **OIL CONDITION** Sodium ASTM D5185(m) 3 ppm The BN result indicates that there is suitable alkalinity remaining in the Boron ASTM D5185(m) O ppm 2 oil. The condition of the oil is suitable for further service. Barium ppm ASTM D5185(m) O 0 Molybdenum ASTM D5185(m) 60 62 ppm ASTM D5185(m) O Manganese ppm <1 Magnesium ASTM D5185(m) 1010 1045 ppm

Calcium

Zinc

Sulfur

Oxidation

Base Number (BN)

Visc @ 100°C

Lubricant Degradation Scale 0-10

Phosphorus

ASTM D5185(m)

ASTM D5185(m)

ASTM D5185(m)

ASTM D7414\*

ASTM D2896\*

ASTM D7279(m)

ASTM D7684\*

ASTM D5185(m) 1150

1070

1270

2060

>25

9.8

15.6

1145

1121

1290

2647

19.9

9.03

14.6

ppm

ppm


ppm

ppm

Abs/.1mm

mg KOH/g

cSt





CALA ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Sample No. Lab Number : 02527542

: WC0700700

**Tested** Diagnosed Unique Number : 5500540 Test Package : MAR 3 To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Received

: 12 Dec 2022 : 12 Dec 2022 - Kevin Marson

: 08 Dec 2022

CCGS GRIFFON, PO BOX 1000, 401 KING ST.W Prescott, ON **CA K6V 5T3** Contact: Mike Rankin

**CANADIAN COAST GUARD** 

mike.rankin@dfo-mpo.gc.ca T: (289)442-0810 F: (519)383-1994

This page left intentionally blank