



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area

SB2

Machine Id

JOHN DEERE SB2 Generator - Kholer 150RE0ZJF (S/N 3379GMJF0005)

Component

Oil

Fluid

JOHN DEERE ENGINE OIL PLUS 50 II 15W40 (28 LTR)

RECOMMENDATION

Resample at the next service interval to monitor. Please specify the component make and model with your next sample. (Customer Sample Comment: Should we change oil and filter?)

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0776677	---	---
Sample Date		Client Info		20 Jun 2023	---	---
Machine Age		Client Info		226	---	---
Oil Age		Client Info		0	---	---
Filter Age		Client Info		0	---	---
Oil Changed		Client Info		Not Changd	---	---
Filter Changed		Client Info		Not Changd	---	---
Sample Status				NORMAL	---	---

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>100	6	---	---
Chromium	ppm	ASTM D5185(m)	>20	0	---	---
Nickel	ppm	ASTM D5185(m)	>4	0	---	---
Titanium	ppm	ASTM D5185(m)		1	---	---
Silver	ppm	ASTM D5185(m)	>3	0	---	---
Aluminum	ppm	ASTM D5185(m)	>20	3	---	---
Lead	ppm	ASTM D5185(m)	>40	<1	---	---
Copper	ppm	ASTM D5185(m)	>330	1	---	---
Tin	ppm	ASTM D5185(m)	>15	0	---	---
Vanadium	ppm	ASTM D5185(m)		<1	---	---

CONTAMINATION












There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	13	---	---
Potassium	ppm	ASTM D5185(m)	>20	2	---	---
Water		WC Method	>0.2	NEG	---	---
Soot %	%	ASTM D7844*	>3	0	---	---
Nitration	Abs/cm	ASTM D7624*	>20	6.3	---	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	21.4	---	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---	---

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185(m)		3	---	---
Boron	ppm	ASTM D5185(m)		251	---	---
Barium	ppm	ASTM D5185(m)		0	---	---
Molybdenum	ppm	ASTM D5185(m)		254	---	---
Manganese	ppm	ASTM D5185(m)		<1	---	---
Magnesium	ppm	ASTM D5185(m)		846	---	---
Calcium	ppm	ASTM D5185(m)		1377	---	---
Phosphorus	ppm	ASTM D5185(m)		925	---	---
Zinc	ppm	ASTM D5185(m)		998	---	---
Sulfur	ppm	ASTM D5185(m)		2552	---	---
Oxidation	Abs/.1mm	ASTM D7414*	>25	16.9	---	---
Base Number (BN)	mg KOH/g	ASTM D2896*	13.6	9.84	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	14.0	---	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0776677 **Received** : 04 Jul 2023
Lab Number : **02567674** **Tested** : 06 Jul 2023
Unique Number : 5604720 **Diagnosed** : 06 Jul 2023 - Kevin Marson
Test Package : MOB 2 (Additional Tests: FT-IR, KV100, TBN)

Watch Tower Bible and Tract Society of Canada
 13893 Highway 7
 Georgetown, ON
 CA L7G 4S4
 Contact: Purchasing Department
 purchase.ca@jw.org
 T: (905)873-4101
 F: (905)873-4508

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.