



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area

Propulsion/Salle des Machines

Machine Id

12A02#03 (S/N M4114-R)

Component

3 Diesel Engine

Fluid

PETRO CANADA RALUBE 40 CFS (720 LTR)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0751424	WC0751396	WC
Sample Date		Client Info		24 Oct 2023	01 Apr 2023	18 Oct 2022
Machine Age	hrs	Client Info		18126	16990	16533
Oil Age	hrs	Client Info		963	4798	4342
Filter Age	hrs	Client Info		963	4798	4342
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Filter Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185(m)	>100	6	10	9
Chromium	ppm	ASTM D5185(m)	>20	0	<1	0
Nickel	ppm	ASTM D5185(m)	>4	<1	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>3	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	2	2	2
Lead	ppm	ASTM D5185(m)	>40	<1	<1	0
Copper	ppm	ASTM D5185(m)	>330	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>15	0	<1	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE

CONTAMINATION





There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	3	3	3
Potassium	ppm	ASTM D5185(m)	>20	0	2	1
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>2	0.1	0.2	0.2
Nitration	Abs/cm	ASTM D7624*	>20	13.3	14.7	15.0
Sulfation	Abs/.1mm	ASTM D7415*	>30	14.7	15.6	16.6
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG

FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)		3	2	2
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	<1	<1
Magnesium	ppm	ASTM D5185(m)	25	19	22	22
Calcium	ppm	ASTM D5185(m)	4300	4709	4974	5019
Phosphorus	ppm	ASTM D5185(m)	1.6	8	3	2
Zinc	ppm	ASTM D5185(m)	2	9	4	4
Sulfur	ppm	ASTM D5185(m)	1500	3063	3132	3090
Oxidation	Abs/.1mm	ASTM D7414*	>25	11.1	12.9	13.5
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	14.4	14.9	14.8



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0751424
Lab Number : 02593083
Unique Number : 5670162
Test Package : MAR 1
Received : 01 Nov 2023
Tested : 01 Nov 2023
Diagnosed : 01 Nov 2023 - Wes Davis

Canadian Coast Guard
 CCGS Amundsen, 101 Boul. Champlain
 Quebec, QC
 CA G1K 7Y7
 Contact: Chief Engineer
 amundsense@ccgs-ngcc.gc.ca
 T: (418)953-8233
 F: x:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.