**WEAR CONTAMINATION FLUID CONDITION**  **NORMAL NORMAL NORMAL** 

[83032]

## 610 BAY ST TORONTO CITY OF TORONTO CITY OF TORONTO

Left Diesel Engine

	_					V	
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0005567		
	Sample Date		Client Info		20 Dec 2023		
	Machine Age	hrs	Client Info		308		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185(m)	>100	1		
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)	>20	0		
	Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)	>3	0		
	Aluminum	ppm	ASTM D5185(m)		2		
	Lead	ppm	ASTM D5185(m)		0		
	Copper	ppm	ASTM D5185(m)		<1		
	Tin	ppm	ASTM D5185(m)		0		
	Vanadium	ppm	ASTM D5185(m)		0		
	White Metal	scalar	Visual*	NONE	NONE		
	Yellow Metal	scalar	Visual*	NONE	NONE		
CONTAMINATION	O'''						
CONTAMINATION	Silicon	ppm	ASTM D5185(m)		2		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)		8		
	Fuel		WC Method		<1.0		
	Water		WC Method	>0.2	NEG		
	Glycol Soot %	%	WC Method	. 0	NEG		
			ASTM D7844*		0		
	Nitration Sulfation	Abs/tmm	ASTM D7624*	>20	6.8 17.4		
	Silt	Abs/.1mm scalar	ASTM D7415* Visual*	>30 NONE	NONE		
	Debris		Visual*	NONE	NONE		
	Sand/Dirt	scalar scalar	Visual*	NONE	NONE		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
	Emulsified Water			>0.2	NEG		
<u></u>	Lindshied Water		Vidual	70.2			
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	<1		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		56		
	Barium	ppm	ASTM D5185(m)		0		
	Molybdenum	ppm	ASTM D5185(m)		15		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)		199		
	Calcium	ppm	ASTM D5185(m)	3780	1853		
	Phosphorus	ppm	ASTM D5185(m)	1370	998		
	Zinc	ppm	ASTM D5185(m)	1500	1102		
	Sulfur	ppm	ASTM D5185(m)	3800	3434		
	Oxidation	Abs/.1mm			13.7		
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	13.9		





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number

: PN0005567

: 02606532 : 5707618

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved

Diagnosed

: 05 Jan 2024 Diagnostician : Wes Davis

: 04 Jan 2024

Test Package : MOB 1 (Additional Tests: Visual)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Ryan Udall rudall@pwrstn.com T: (905)565-1621 F: (905)629-1499

Report Id: POWMIS [WCAMIS] 02606532 (Generated: 01/08/2024 08:13:05) Rev: 1

Contact/Location: Ryan Udall - POWMIS