## B POWER GENERATION PRODUCTS

**OIL ANALYSIS REPORT** 

WEAR NORMAL CONTAMINATION NORMAL FLUID CONDITION NORMAL

## [83654] Machine Id 19 GREEN BELT DR NORTH YORK EA GROUP 62B10434

## Rear Diesel Engine

Area


## ESSO XD-3 EXTRA 15W40 (40 LTR)


ESSU XD-3 EXTRA 15W40 (40 LTR)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0005739	PN0004421	
	Sample Date		Client Info		05 Jan 2024	19 Dec 2022	
	Machine Age	hrs	Client Info		106	102	
	Oil Age	hrs	Client Info		102	0	
	Filter Age	hrs	Client Info		102	0	
	Oil Changed		Client Info		Changed	Changed	
	Filter Changed		Client Info		Not Changd	Changed	
	Sample Status				NORMAL	NORMAL	
WEAR	Iron	ppm	ASTM D5185(m)	>100	1	2	
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)	>20	0	0	
	Nickel	ppm	ASTM D5185(m)	>2	0	0	
	Titanium	ppm	ASTM D5185(m)	>2	1	5	
	Silver	ppm	ASTM D5185(m)	>2	<1	<1	
	Aluminum	ppm	ASTM D5185(m)	>25	2	1	
	Lead	ppm	ASTM D5185(m)	>40	8	18	
	Copper	ppm	ASTM D5185(m)	>330	311	798	
	Tin	ppm	ASTM D5185(m)	>15	0	<1	
	Vanadium	ppm	ASTM D5185(m)		0	0	
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	5	5	
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1	<1	
	Fuel		WC Method	>5	<1.0	<1.0	
	Water		WC Method	>0.2	NEG	NEG	
	Glycol		WC Method		NEG	NEG	
	Soot %	%	ASTM D7844*	>3	0	0	
	Nitration	Abs/cm	ASTM D7624*	>20	6.7	4.9	
	Sulfation	Abs/.1mm	ASTM D7415*	>30	17.5	16.0	
	Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	2	5	
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		52	50	
	Barium	ppm	ASTM D5185(m)		0	0	
	Molybdenum	ppm	ASTM D5185(m)		30	46	
	Manganese	ppm	ASTM D5185(m)		0	<1	
	Magnesium	ppm	ASTM D5185(m)		429	670	
	Calcium	ppm	ASTM D5185(m)	3780	1676	1525	
	Phosphorus	ppm	ASTM D5185(m)	1370	1002	1090	
	Zinc	ppm	ASTM D5185(m)	1500	1119	1170	
	Sulfur	ppm	ASTM D5185(m)	3800	3066	2754	
	Oxidation	Abs/.1mm	ASTM D7414*	>25	13.3	9.8	
	Visc @ 40°C	cSt	ASTM D7279(m)	116	103		
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	14.3	14.3	

Viscosity Index (VI) Scale ASTM D2270\* 140

Contact/Location: Ryan Udall - POWMIS

142





POWER STATION INC. Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PN0005739 Recieved : 09 Jan 2024 1050 JAYSON COURT Ĥ Lab Number : 02607451 MISSISSAUGA, ON Diagnosed : 09 Jan 2024 ISO 17025:2017 Accredited Laboratory : 5708537 Diagnostician : Wes Davis CA L4W 2V5 Unique Number Test Package : MOB 1 (Additional Tests: KV40, VI) Contact: Ryan Udall To discuss this sample report, contact Customer Service at 1-800-268-2131. rudall@pwrstn.com T: (905)565-1621 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)629-1499