

Machine Id

JOHN DEERE 644K LDR009

Component Coolant

EXTENDED LIFE COOLANT (--- GAL)

RECOMMENDATION

We recommend that you drain the system and refill with a 50/50 longlife coolant/water mixture. We recommend an early resample to monitor this condition.

CORROSION

Copper ppm levels are abnormal. The high metal levels indicate corrosion in the system.


CONTAMINANTS

There is no indication of any contamination in the coolant.

COOLANT CONDITION

The nitrite level is acceptable. The pH is low which causes rust formation. The reserve alkalinity of this fluid is acceptable.

	JAL)						
	Test	UOM	Method	Limit/Abn	Current	History1	History2
	Sample Number		Client Info		WC0892477		
	Sample Date		Client Info		08 Jan 2024		
	Machine Age	hrs	Client Info		111363		
	Oil Age	hrs	Client Info		0		
	Oil Changed		Client Info		Not Changd		
	Sample Status				ABNORMAL		
	Iron	ppm	ASTM D5185(m)	>15	7		
	Aluminum	ppm	ASTM D5185(m)	>10	2		
	Copper	ppm	ASTM D5185(m)	>10	- ▲ 39		
	Lead	ppm	ASTM D5185(m)	>10	0		
	Tin	ppm	ASTM D5185(m)	>10	0		
	Silver	ppm	ASTM D5185(m)	>10	<1		
	Zinc	ppm	ASTM D5185(m)	>10	12		
	Calcium	ppm	ASTM D5185(m)	>100	8		
	Magnesium	ppm	ASTM D5185(m)	>40	2		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
	Coolant Appearance		Visual*	Clear	Clear		
	Specific Gravity		ASTM D1298*		1.075		
	рН	Scale 0-14	ASTM D1287*	9.0	6.85		
	Nitrites	ppm	Alcan Test Kit*		840		
	Reserve Alkalinity	Scale 0-20	ASTM D1121*		4.8		
	Percentage Glycol	%	ASTM D3321*	50	56.0		
	Freezing Point	°C	ASTM D3321*	-40	-50		
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		121		
	Phosphorus	ppm	ASTM D5185(m)		53		
	Boron	ppm	ASTM D5185(m)		855		
	Molybdenum	ppm	ASTM D5185(m)		136		
	Sodium	ppm	ASTM D5185(m)		10088		
	Potassium	ppm	ASTM D5185(m)		289		
	Coolant Color		Visual*	Orange/R	Red		
				0	\smile		



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Agnico Eagle Canada CALA Sample No. : WC0892477 Recieved : 11 Jan 2024 1350 Government Rd. W, MACASSA COMPLEX Lab Number : 02608326 Kirkland Lake, ON Diagnosed : 14 Jan 2024 ISO 17025:2017 Accredited Laboratory : 5709412 Unique Number Diagnostician : Kevin Marson CA P2N 3J1 Test Package : COOL Contact: Jay Gould MacassaMobileUGPlanning@agnicoeagle.com To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (705)567-5208 Validity of results and interpretation are based on the sample and information as supplied. F: (705)567-5221

5