



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
[4397]
 Machine Id
01-001-CE
 Component
New (Unused) Oil
 Fluid
PETRO CANADA LUMINOL TRI (--- GAL)

RECOMMENDATION

This is a baseline read-out on the submitted sample.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PP0000881	PP0000874	---
Sample Date		Client Info		10 Jan 2024	04 Jan 2024	---
Machine Age	hrs	Client Info		0	0	---
Oil Age	hrs	Client Info		0	0	---
Filter Age	hrs	Client Info		0	0	---
Oil Changed		Client Info		N/A	N/A	---
Filter Changed		Client Info		N/A	N/A	---
Sample Status				NORMAL	NORMAL	---

WEAR

{not applicable}

Iron	ppm	ASTM D5185(m)	>5	0	0	---
Chromium	ppm	ASTM D5185(m)	>5	0	0	---
Nickel	ppm	ASTM D5185(m)	>5	0	<1	---
Titanium	ppm	ASTM D5185(m)		0	0	---
Silver	ppm	ASTM D5185(m)	>5	0	0	---
Aluminum	ppm	ASTM D5185(m)	>5	<1	<1	---
Lead	ppm	ASTM D5185(m)	>5	0	0	---
Copper	ppm	ASTM D5185(m)	>5	0	0	---
Tin	ppm	ASTM D5185(m)	>5	0	0	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---

CONTAMINATION

{not applicable}

Silicon	ppm	ASTM D5185(m)	>15	0	0	---
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	---
Water		WC Method		NEG	NEG	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---

FLUID CONDITION

Pour Point = -60°C.

Sodium	ppm	ASTM D5185(m)	>5	0	0	---
Boron	ppm	ASTM D5185(m)	0	0	0	---
Barium	ppm	ASTM D5185(m)	0	0	0	---
Molybdenum	ppm	ASTM D5185(m)	0	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	0	---
Magnesium	ppm	ASTM D5185(m)	0	<1	0	---
Calcium	ppm	ASTM D5185(m)	0	0	0	---
Phosphorus	ppm	ASTM D5185(m)	0	0	0	---
Zinc	ppm	ASTM D5185(m)	0	<1	<1	---
Sulfur	ppm	ASTM D5185(m)	10	0	0	---
Pour Point	°C	ASTM D97*	-60	-60	-63	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP0000881
Lab Number : **02608329**
Unique Number : 5709415
Test Package : TEST (Additional Tests: ICP, PourPt, Visual)

Recieved : 11 Jan 2024
Diagnosed : 15 Jan 2024
Diagnostician : Kevin Marson

*To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.*

Oleo Energies
5800 Thorold Stone Road
Niagara Falls, ON
CA L2J 1A2
Contact: Mark Michalkoff
mmichalkoff@oleoenergies.com
T: (905)358-5133
F: