## B POWER GENERATION PRODUCTS

**OIL ANALYSIS REPORT** 

## [83279] Additione Id 439 SHERBOURNE ST TORONTO CITY OF TORONTO CITY OF TORONTO

## Component Right Diesel Engine

## ESSO XD-3 EXTRA 15W40 (20 LTR)

Area

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0005527		
	Sample Date		Client Info		15 Dec 2023		
	Machine Age	hrs	Client Info		852		
	Oil Age	hrs	Client Info		69		
	Filter Age	hrs	Client Info		69		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185(m)	>90	2		
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)	>20	0		
	Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)	>20	2		
	Lead	ppm	ASTM D5185(m)	>40	<1		
	Copper	ppm	ASTM D5185(m)	>330	<1		
	Tin	ppm	ASTM D5185(m)	>15	0		
	Vanadium	ppm	ASTM D5185(m)		0		
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	7		
The water content is negligible. There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1		
	Fuel		WC Method	>3.0	<1.0		
	Water	%	ASTM D6304*	>0.2	0.033		
	ppm Water	ppm	ASTM D6304*	>2000	333		
	Glycol	%	ASTM D7922*		NEG		
	Soot %	%	ASTM D7844*	>6	0		
	Nitration	Abs/cm	ASTM D7624*	>20	5.3		
	Sulfation	Abs/.1mm	ASTM D7415*	>30	18.9		
	Emulsified Water	scalar	Visual*	>0.2	.2%		
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	2		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		168		
	Barium	ppm	ASTM D5185(m)		0		
	Molybdenum	ppm	ASTM D5185(m)		65		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)		331		
	Calcium	ppm	ASTM D5185(m)	3780	1734		
	Phosphorus	ppm	ASTM D5185(m)	1370	1016		
	Zinc	ppm	ASTM D5185(m)	1500	1115		
	Sulfur	ppm	ASTM D5185(m)	2000	3002		

Oxidation

Visc @ 100°C cSt


Abs/.1mm ASTM D7414\* >25

ASTM D7279(m) 15.4

Contact/Location: Brett Kinkley - POWMIS

14.1

13.1



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 POWER STATION INC. CALA Sample No. : PN0005527 Recieved : 12 Jan 2024 1050 JAYSON COURT Ĺİ. Lab Number : 02608518 MISSISSAUGA, ON Diagnosed : 16 Jan 2024 ISO 17025:2017 : 5709604 Diagnostician : Kevin Marson Accredited CA L4W 2V5 Unique Number Laboratory Test Package : MOB 1 (Additional Tests: Glycol, KF) Contact: Brett Kinkley To discuss this sample report, contact Customer Service at 1-800-268-2131. Bkinkley@pwrstn.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: Validity of results and interpretation are based on the sample and information as supplied. F: (905)565-8544