Station **POWER GENERATION PRODUCTS**

OIL ANALYSIS REPORT

Limit/Abn Current

History1

History₂

[83200]

400 THE WEST MALL TORONTO WESTBURN MANOR CITY OF TORONTO RG6081A154829

Test

LIOM

Method

Rear Diesel Engine

Area

ESSO XD-3 EXTRA 15W40 (30 LTR)

RECOMMENDATION

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.	Sample Number		Client Info		PN0005523	PN0001815	PN0000516
	Sample Date		Client Info		12 Dec 2023	02 Nov 2020	20 Sep 2019
	Machine Age	hrs	Client Info		648	469	430
	Oil Age	hrs	Client Info		520	40	19
	Filter Age	hrs	Client Info		520	40	19
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185(m)	>51	4	4	3
	Chromium	ppm	ASTM D5185(m)		0	<1	<1
Metal levels are typical for a new component breaking in.	Nickel	ppm	ASTM D5185(m)		ہ <1	<1	<1
	Titanium	ppm	ASTM D5185(m)		0	0	<1
	Silver	ppm	ASTM D5185(m)	>3	0	<1	<1
	Aluminum	ppm	ASTM D5185(m)	>31	2	<1	<1
	Lead	ppm	ASTM D5185(m)	>26	<1	<1	<1
	Copper	ppm	ASTM D5185(m)	>26	<1	<1	<1
	Tin	ppm	ASTM D5185(m)	>4	0	<1	<1
	Vanadium	ppm	ASTM D5185(m)		0	0	0
	Silicon	ppm	ASTM D5185(m)	<u>_</u> 22	5	8	8
There is a moderate amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.	Potassium	ppm	ASTM D5185(m)	>20	0	1	<1
	Fuel	%	ASTM D7593*	>2.1	▲ 2.5	<1.0	1.6
	Water		WC Method		NEG	NEG	NEG
	Glycol	%	ASTM D7922*		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	5.5	5.4	5.4
	Sulfation	Abs/.1mm	ASTM D7415*	>30	19.8	21.0	23.3
	Emulsified Water	scalar	Visual*	>0.21	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	1	3	2
The oil is no longer serviceable due to the presence of contaminants.	Boron	ppm	ASTM D5185(m)		234	67	57
The on is no longer serviceable due to the presence of contaminants.	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		71	28	39
	Manganese	ppm	ASTM D5185(m)		0	<1	<1
	Magnesium	ppm	ASTM D5185(m)		333	540	474
	Calcium	ppm	ASTM D5185(m)	3780	1752	1493	1623
	Phosphorus	ppm	ASTM D5185(m)	1370	1044	704	740
	Zinc	ppm	ASTM D5185(m)	1500	1162	847	852
						4	

Sulfur

Oxidation

Visc @ 100°C cSt

Contact/Location: Ryan Udall - POWMIS

3025

14.9

12.8

2240

17.5

12.5

ASTM D5185(m) 3800

ASTM D7279(m) 15.4

>25

ASTM D7414*


ppm

Abs/.1mm

2104

18.7

13.0



POWER STATION INC. Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA : PN0005523 Recieved 1050 JAYSON COURT Sample No. : 12 Jan 2024 : 02608519 MISSISSAUGA, ON Lab Number Diagnosed : 15 Jan 2024 ISO 17025:2017 : 5709605 Accredited CA L4W 2V5 Unique Number Diagnostician : Kevin Marson Laboratory Test Package : MOB 1 (Additional Tests: FuelDilution, Glycol, PercentFuel) Contact: Ryan Udall To discuss this sample report, contact Customer Service at 1-800-268-2131. rudall@pwrstn.com T: (905)565-1621 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)629-1499

Contact/Location: Ryan Udall - POWMIS