POWER GENERATION PRODUCTS

OIL ANALYSIS REPORT

Current

PN0005747

History1

History2

Limit/Abn

[83675] Machine Id 4310 QUEEN ST NIAGARA FALLS REGION OF NIAGARA REGION OF NIAGARA

Test

Sample Number

UOM

Method

Client Info

Rear Diesel Engine

ESSO XD-3 EXTRA 15W40 (10 LTR)

R	EC	OM	MEN	IDA1	ΓΙΟΝ	

No corrective action is recommended at this time. Resample at the next service interval to monitor.

 _	

Δro

Metal levels are typical for a new component breaking in.

CONT	ATION	

Fuel content negligible. Elevated aluminum (AI) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.

Sample Date		Client Info		08 Jan 2024	
Machine Age	hrs	Client Info		260	
Oil Age	hrs	Client Info		0	
Filter Age	hrs	Client Info		0	
Oil Changed		Client Info		Changed	
Filter Changed		Client Info		Not Changd	
Sample Status				NORMAL	
Iron	ppm	ASTM D5185(m)	>100	15	
Chromium	ppm	ASTM D5185(m)	>20	<1	
Nickel	ppm	ASTM D5185(m)	>4	<1	
Titanium	ppm	ASTM D5185(m)		91	
Silver	ppm	ASTM D5185(m)	>3	0	
Aluminum	ppm	ASTM D5185(m)	>20	6	
Lead	ppm	ASTM D5185(m)	>40	20	
Copper	ppm	ASTM D5185(m)	>330	3	
Tin	ppm	ASTM D5185(m)	>15	7	
Vanadium	ppm	ASTM D5185(m)		0	
Silioon		ASTM D5185(m)	. 05	121	
Silicon	ppm		>25		
Potassium	ppm	ASTM D5185(m)	>20	<1	
Fuel	%	ASTM D7593*	>5	0.6	
Water		WC Method	>0.2	NEG	
Glycol	0/	WC Method	0	NEG	
Soot %	%	ASTM D7844*	>3	0	
Nitration	Abs/cm	ASTM D7624*	>20	8.6	
Sulfation	Abs/.1mm	ASTM D7415*	>30	29.2	
Emulsified Water	scalar	Visual*	>0.2	NEG	
Sodium	ppm	ASTM D5185(m)	>192	10	
Boron	ppm	ASTM D5185(m)		84	
Barium	ppm	ASTM D5185(m)		<1	
Molybdenum	ppm	ASTM D5185(m)		23	
Manganese	ppm	ASTM D5185(m)		3	
Magnesium	ppm	ASTM D5185(m)		342	
Calcium	ppm	ASTM D5185(m)	3780	1909	
Phosphorus	ppm	ASTM D5185(m)	1370	741	
Zinc	ppm	ASTM D5185(m)	1500	835	
Sulfur	ppm	ASTM D5185(m)	3800	2885	
Oxidation	Abs/.1mm	ASTM D7414*	>25	19.0	
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	9.6	

FLUID CONDITION

Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The condition of the oil is acceptable for the time in service.

Contact/Location: Brett Kinkley - POWMIS



POWER STATION INC. Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PN0005747 Recieved : 12 Jan 2024 1050 JAYSON COURT Lab Number : 02608525 Diagnosed MISSISSAUGA, ON : 15 Jan 2024 ISO 17025:2017 : 5709611 Diagnostician : Kevin Marson Accredited CA L4W 2V5 Unique Number Laboratory Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel) Contact: Brett Kinkley To discuss this sample report, contact Customer Service at 1-800-268-2131. Bkinkley@pwrstn.com Т: Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)565-8544