
WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL ABNORMAL

3401 DORCHESTER NIAGARA FALLS REGION OF NIAGARA REGION OF NIAGARA

Component Rear Natural Gas Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0005743		
	Sample Date		Client Info		09 Jan 2024		
	Machine Age	hrs	Client Info		98		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				ABNORMAL		
WEAR	lvon		ACTM DE10E(m)	. 50			
	Iron	ppm	ASTM D5185(m)		2		
Metal levels are typical for a new component breaking in.	Chromium Nickel	ppm	ASTM D5185(m)		0		
		ppm	ASTM D5185(m)	>2	0		
	Titanium Silver	ppm	ASTM D5185(m) ASTM D5185(m)	. 0	75 0		
	Aluminum	ppm	, ,	>3			
	Lead	ppm	ASTM D5185(m) ASTM D5185(m)	>30	3 0		
		ppm	, ,		2		
	Copper	ppm	ASTM D5185(m) ASTM D5185(m)	>35	0		
	Vanadium	ppm	, ,	>4			
·	variadium	ppm	ASTM D5185(m)		0 		
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>+100	4		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1		
	Water		WC Method	>0.1	NEG		
	Soot %	%	ASTM D7844*		0		
	Nitration	Abs/cm	ASTM D7624*	>20	4.6		
	Sulfation	Abs/.1mm	ASTM D7415*	>30	14.0		
	Emulsified Water	scalar	Visual*	>0.1	NEG		
FLUID CONDITION	Co alicina		ACTM DE10E()	100			
	Sodium	ppm	ASTM D5185(m)	>192	2		
Viscosity of sample indicates oil is within SAE 20 range, advise investigate. The condition of the oil is acceptable for the time in service.	Boron Barium	ppm	ASTM D5185(m) ASTM D5185(m)		156 0		
	Molybdenum	ppm	ASTM D5185(m)		22		
		ppm					
	Maganese	ppm	ASTM D5185(m) ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m) ASTM D5185(m)	2790	507		
	Calcium	ppm	()	3780	1462		
	Phosphorus	ppm	ASTM D5185(m)		684 756		
	Zinc	ppm	ASTM D5185(m)	1500	756		
	Sulfur	ppm Abo/1mm	ASTM D7414*	3800	2782		
	Oxidation	Abs/.1mm	ASTM D7414*	>20	7.2		





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number

: PN0005743 : 02608528

Unique Number : 5709614 Test Package : MOB 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved : 12 Jan 2024 Diagnosed : 14 Jan 2024 Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com

F: (905)565-8544