
WEAR CONTAMINATION FLUID CONDITION **NORMAL NORMAL NORMAL**

[83735]

1090 NUVIK CRT MISSISSAUGA, FIRE STATION 117 CITY OF MISSISSAUGA CITY OF MISSISSAUGA

Right Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. No other corrective action is recommended at this time.	Sample Number		Client Info		PN0005662	PN0003198	PN000075
	Sample Date		Client Info		11 Jan 2024	07 Jan 2022	10 Feb 202
	Machine Age	hrs	Client Info		221	185	153
	Oil Age	hrs	Client Info		204	0	0
	Filter Age	hrs	Client Info		204	0	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Not Changd	Changed	Change
	Sample Status				NORMAL	NORMAL	ABNORMA
WEAR	Iron	ppm	ASTM D5185(m)	>100	1	2	2
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)		0	0	<1
	Nickel	ppm	ASTM D5185(m)		0	<1	<1
	Titanium	ppm	ASTM D5185(m)		0	0	<1
	Silver	ppm	ASTM D5185(m)	>3	0	0	0
	Aluminum	ppm	ASTM D5185(m)	>20	2	2	<1
	Lead	ppm	ASTM D5185(m)	>40	<1	1	1
	Copper	ppm	ASTM D5185(m)	>330	3	7	5
	Tin	ppm	ASTM D5185(m)	>15	<1	1	1
	Vanadium	ppm	ASTM D5185(m)		0	0	0
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	2	4	5
Light fuel dilution occurring. No other contaminants were detected in the oil.	Potassium	ppm	ASTM D5185(m)		0	<1	<1
	Fuel	%	ASTM D7593*	>5	1.2	<1.0	▲ 3.3
	Water		WC Method	>0.2	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	5.8	7.5	5.7
	Sulfation	Abs/.1mm	ASTM D7415*	>30	15.5	18.7	24.1
	Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	1	3	1
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		55	76	51
	Barium	ppm	ASTM D5185(m)		0	0	<1
	Molybdenum	ppm	ASTM D5185(m)		31	70	35
	Manganese	ppm	ASTM D5185(m)		0	<1	<1
	Magnesium	ppm	ASTM D5185(m)		114	183	425
	Calcium	ppm	ASTM D5185(m)	3780	1992	1990	1607
	Phosphorus	ppm	ASTM D5185(m)	1370	973	985	△ 694
	Zinc	ppm	ASTM D5185(m)	1500	1068	1117	<u>▲</u> 815
	Sulfur	ppm	ASTM D5185(m)		3052	3067	2173
	Oxidation	Abs/.1mm	ASTM D7414*		10.3	14.7	18.3
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	13.0	13.9	11.9





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number **Unique Number**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PN0005662

: 02608965 : 5710051

Recieved

: 16 Jan 2024 Diagnosed : 17 Jan 2024 Diagnostician : Wes Davis

Test Package: MOB 1 (Additional Tests: FuelDilution, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT

MISSISSAUGA, ON CA L4W 2V5 Contact: Ryan Udall rudall@pwrstn.com T: (905)565-1621

F: (905)629-1499