WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL NORMAL

Machine Id

7300 INDUSTRIAL PKWY ALLISTON NEW TECUMSEH NEW TECUMSEH

Component Rear Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0005661		
	Sample Date		Client Info		10 Jan 2024		
	Machine Age	hrs	Client Info		632		
	Oil Age	hrs	Client Info		4		
	Filter Age	hrs	Client Info		4		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185(m)	>200	4		
	Chromium	ppm	ASTM D5185(m)		0		
Metal levels are typical for a new component breaking in.	Nickel	ppm	ASTM D5185(m)		<1		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)		<1		
	Lead	ppm	ASTM D5185(m)	>30	1		
	Copper	ppm	ASTM D5185(m)	>30	2		
	Tin	ppm	ASTM D5185(m)	>15	<1		
	Vanadium	ppm	ASTM D5185(m)		0		
CONTAMINATION	0		10TH B= (05/)				
CONTAMINATION	Silicon	ppm	ASTM D5185(m)		6		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)		0		
	Fuel		WC Method		<1.0		
	Water Glycol		WC Method WC Method	>0.2	NEG NEG		
	Soot %	%	ASTM D7844*	>3	0		
	Nitration	Abs/cm	ASTM D7624*	>20	3.2		
	Sulfation	Abs/.1mm	ASTM D7415*		12.8		
	Emulsified Water		Visual*	>0.2	NEG		
LUD CONDITION			AOTM D5405()	40			
LUID CONDITION	Sodium	ppm	ASTM D5185(m)	>16	<1		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		4		
	Barium Molybdenum	ppm	ASTM D5185(m) ASTM D5185(m)		0 3		
	Manganese	ppm	ASTM D5185(III) ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)		721		
	Calcium	ppm	ASTM D5185(m)	2550	1412		
	Phosphorus	ppm	ASTM D5185(m)	1000	969		
	Zinc	ppm	ASTM D5185(m)	1120	1081		
	Sulfur	ppm	ASTM D5185(m)	1120	2597		
	Oxidation	Abs/.1mm	ASTM D7414*	>25	5.8		
	C. addition			0	3.0		





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number

: PN0005661 Unique Number : 5710052

: 02608966 Test Package : MOB 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved : 16 Jan 2024 : 16 Jan 2024 Diagnosed : Wes Davis

Diagnostician

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com

F: (905)565-8544