



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
THORNES ENTERPRISES LTD
 Machine Id
RG6090L127896
 Component
Port Genset
 Fluid
IRVING IDO UNIVERSAL SAE 15W40 (31 LTR)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		OF0000354	OF0000194	WC101281
Sample Date		Client Info		15 Dec 2023	17 May 2021	06 Apr 2019
Machine Age	hrs	Client Info		0	2333	994
Oil Age	hrs	Client Info		260	245	530
Filter Age	hrs	Client Info		260	245	530
Oil Changed		Client Info		Not Changd	Changed	Changed
Filter Changed		Client Info		Not Changd	Changed	Changed
Sample Status				NORMAL	ATTENTION	NORMAL

WEAR

All component wear rates are normal.

PQ		ASTM D8184*		0	0	11
Iron	ppm	ASTM D5185(m)	>50	2	3	5
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>5	0	<1	<1
Aluminum	ppm	ASTM D5185(m)	>12	2	2	2
Lead	ppm	ASTM D5185(m)	>17	0	4	2
Copper	ppm	ASTM D5185(m)	>70	<1	▲ 100	2
Tin	ppm	ASTM D5185(m)	>15	0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0

CONTAMINATION












There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	2	5	6
Potassium	ppm	ASTM D5185(m)	>20	<1	0	2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	8.1	9.1	8.1
Sulfation	Abs/.1mm	ASTM D7415*	>30	17.8	19.0	18.6
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185(m)		1	<1	2
Boron	ppm	ASTM D5185(m)		38	26	89
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		10	7	39
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)		153	35	126
Calcium	ppm	ASTM D5185(m)		2032	2137	1986
Phosphorus	ppm	ASTM D5185(m)		1039	1001	977
Zinc	ppm	ASTM D5185(m)	1300	1174	1197	1111
Sulfur	ppm	ASTM D5185(m)		3420	3426	3284
Oxidation	Abs/.1mm	ASTM D7414*	>25	13.4	13.8	13.6
Base Number (BN)	mg KOH/g	ASTM D2896*	11.3	9.29	6.69	7.37
Visc @ 100°C	cSt	ASTM D7279(m)	15.2	14.1	13.6	12.7



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : OF0000354 **Received** : 17 Jan 2024
Lab Number : 02609281 **Diagnosed** : 18 Jan 2024
Unique Number : 5710367 **Diagnostician** : Wes Davis
Test Package : MOB 2 (Additional Tests: PQ)

Oil Filtration Solutions Ltd.
 PO BOX 16125
 CONCEPTION BAY SOUTH, NL
 CA A1X 2E2
 Contact: BILL BUTLER
 BBUTLER@OILFILTRATIONSOLUTIONS.COM
 T: (709)834-8433
 F: (709)834-8435

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.