



# OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area  
**(NAH) NORTHWESTERN AIR LEASE [52904]**  
Machine Id  
**[NAH] JETSTREAM BAE J32 P-66274C (S/N 929)**  
Component  
**Left Jet Turbine**  
Fluid  
**BP TURBO OIL 2380 (--- GAL)**

## RECOMMENDATION

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>GT57347</b>	GT57035	GT56834
Sample Date		Client Info		<b>09 Jan 2024</b>	05 Oct 2023	05 Jul 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>212</b>	0	584
Filter Age	hrs	Client Info		<b>212</b>	202	177
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>---</b>	---	NORMAL

## WEAR







Iron	ppm	ASTM D5185(m)	>8	<b>0</b>	0	0
Chromium	ppm	ASTM D5185(m)	>2	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185(m)	>2	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>2	<b>&lt;1</b>	<1	1
Lead	ppm	ASTM D5185(m)	>3	<b>0</b>	0	<1
Copper	ppm	ASTM D5185(m)	>3	<b>0</b>	0	0

## CONTAMINATION

Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
-------	--	-----------	------	------------	-----	-----

## FLUID CONDITION

Magnesium	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Acid Number (AN)	mg KOH/g	ASTM D974*	0.43	<b>0.54</b>	0.64	0.57
Visc @ 40°C	cSt	ASTM D7279(m)	24.2	<b>---</b>	---	24.1



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : GT57347 **Received** : 22 Jan 2024  
**Lab Number** : 02610494 **Diagnosed** : 22 Jan 2024  
**Unique Number** : 5711580 **Diagnostician** :  
**Test Package** : G331 ( Additional Tests: ICP )

**Honeywell Engines**  
 111 S. 34th Street, 301 Receiving, Attn: SOAP Program  
 PHOENIX, AZ  
 US 85034  
 Contact: GARRETT

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
 F: (602)365-2676