MOB

POWERStation
WWW.POWERSTATIONGENERATORS.COM
POWER GENERATION PRODUCTS

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	ABNORMAL

Machine Id
215 INDUSTRIAL PKWY AURORA TOWN OF AURORA TOWN OF AURORA
Component
Rear Diesel Engine
Fluid
ESSO XD-3 EXTRA 15W40 (40 LTR)

RECOMMENDATION

The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

WEAR

All component wear rates are normal.

CONTAMINATION

There is a moderate amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

FLUID CONDITION

Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0005833	---	---
Sample Date		Client Info		12 Feb 2024	---	---
Machine Age	hrs	Client Info		1390	---	---
Oil Age	hrs	Client Info		20	---	---
Filter Age	hrs	Client Info		20	---	---
Oil Changed		Client Info		Changed	---	---
Filter Changed		Client Info		Changed	---	---
Sample Status				ABNORMAL	---	---
Iron	ppm	ASTM D5185(m)	>200	2	---	---
Chromium	ppm	ASTM D5185(m)	>20	0	---	---
Nickel	ppm	ASTM D5185(m)	>2	<1	---	---
Titanium	ppm	ASTM D5185(m)	>2	0	---	---
Silver	ppm	ASTM D5185(m)	>2	0	---	---
Aluminum	ppm	ASTM D5185(m)	>30	1	---	---
Lead	ppm	ASTM D5185(m)	>30	<1	---	---
Copper	ppm	ASTM D5185(m)	>30	3	---	---
Tin	ppm	ASTM D5185(m)	>15	0	---	---
Vanadium	ppm	ASTM D5185(m)		0	---	---
Silicon	ppm	ASTM D5185(m)	>30	4	---	---
Potassium	ppm	ASTM D5185(m)	>20	6	---	---
Fuel	%	ASTM D7593*	>3.0	▲ 4.2	---	---
Water		WC Method	>0.2	NEG	---	---
Glycol		WC Method		NEG	---	---
Soot %	%	ASTM D7844*	>3	0	---	---
Nitration	Abs/cm	ASTM D7624*	>20	5.6	---	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	20.0	---	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---	---
Sodium	ppm	ASTM D5185(m)	>192	2	---	---
Boron	ppm	ASTM D5185(m)		146	---	---
Barium	ppm	ASTM D5185(m)		0	---	---
Molybdenum	ppm	ASTM D5185(m)		13	---	---
Manganese	ppm	ASTM D5185(m)		<1	---	---
Magnesium	ppm	ASTM D5185(m)		180	---	---
Calcium	ppm	ASTM D5185(m)	3780	1876	---	---
Phosphorus	ppm	ASTM D5185(m)	1370	960	---	---
Zinc	ppm	ASTM D5185(m)	1500	1060	---	---
Sulfur	ppm	ASTM D5185(m)	3800	2972	---	---
Oxidation	Abs/.1mm	ASTM D7414*	>25	16.3	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	▲ 13.0	---	---

Fuel Dilution



Viscosity @ 100°C

Iron (ppm)



Lead (ppm)



Aluminum (ppm)



Chromium (ppm)



Copper (ppm)



Silicon (ppm)



Viscosity @ 100°C



Fuel Dilution



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PN0005833 **Received** : 15 Feb 2024
Lab Number : 02615912 **Tested** : 16 Feb 2024
Unique Number : 5733022 **Diagnosed** : 16 Feb 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.
1050 JAYSON COURT
MISSISSAUGA, ON
CA L4W 2V5
Contact: Brett Kinkley
Bkinkley@pwrstn.com
T:
F: (905)565-8544