



POWER SYSTEMS
SYSTÈMES DE PUISSANCE

OIL ANALYSIS REPORT

CORROSION	NORMAL
CONTAMINANTS	ABNORMAL
FUEL CONDITION	ABNORMAL

Area
[59462]
Machine Id
TG.180
Component
Diesel Fuel
Fluid
{not provided} (--- GAL)

RECOMMENDATION

Nous vous recommandons de vérifier tous les endroits par lesquels des contaminants peuvent pénétrer dans le système. Nous vous recommandons de vidanger le carburant de ce composant si vous ne l'avez pas déjà fait.

CORROSION

{sans objet}




CONTAMINANTS

L'échantillon contenait une couche visible de contaminants fluide étrangers.

FUEL CONDITION

Teneur en urée est élevée . le carburant ne peut plus être utilisée en raison de la présence de contaminants.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WA0021136	---	---
Sample Date		Client Info		12 Feb 2024	---	---
Machine Age	hrs	Client Info		0	---	---
Sample Status				ABNORMAL	---	---
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Hydrocarbon	scalar	In-House*		▲ MODERATE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	▲ HAZY	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Urea Content	%	ISO 22241*	<31.8	32.2	---	---
Density @ 20°C	g/cm3	ISO 22241*	>1.0930	▲ 1.0853	---	---
Refracting Index		ISO 22241*	<1.3814	1.3821	---	---
Appearance	scalar	Visual*		▲ Cloudy	---	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0021136
Lab Number : 02616497
Unique Number : 5733607
Test Package : DEF 1
Received : 16 Feb 2024
Tested : 22 Feb 2024
Diagnosed : 22 Feb 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Wajax Limited
 2997 AV. WATT
 Quebec, QC
 CA G1X 3W1
 Contact: Steve Racine
 sracine@wajax.com
 T:
 F: (418)651-4448