
## **CORROSION CONTAMINANTS COOLANT CONDITION**

**NORMAL NORMAL NORMAL** 

Machine Id 10003

Component Coolant

{not provided} ( GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service. Resample at the next service interval to monitor.	Sample Number		Client Info		WC0890738	WC0713496	
	Sample Date		Client Info		09 Feb 2024	16 Dec 2022	
	Machine Age	hrs	Client Info		1990	3067	
	Oil Age	hrs	Client Info		1990	500	
	Oil Changed		Client Info		Changed	N/A	
	Sample Status				NORMAL	NORMAL	
CORROSION	Iron	ppm	ASTM D5185(m)	>15	0	7	
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D5185(m)	>10	0	4	
	Copper	ppm	ASTM D5185(m)	>10	<1	4	
	Lead	ppm	ASTM D5185(m)	>10	0	0	
	Tin	ppm	ASTM D5185(m)	>10	0	0	
	Silver	ppm	ASTM D5185(m)	>10	<1	1	
	Zinc	ppm	ASTM D5185(m)	>10	1	10	
CONTAMINANTS	Calcium	ppm	ASTM D5185(m)	>100	5	8	
There is no indication of any contamination in the coolant.	Magnesium	ppm	ASTM D5185(m)	>40	1	5	
	Appearance	scalar	Visual*	NORML	NORML	NORML	
	Odor	scalar	Visual*	NORML	NORML	NORML	
	Coolant Appearance		Visual*	Clear	Clear	Clear	
COOLANT CONDITION	Specific Gravity		ASTM D1298*		1.065	1.068	
The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits.	рН	Scale 0-14	ASTM D1287*		8.74	7.75	
	Nitrites	ppm	Alcan Test Kit*		1280	480	
	Reserve Alkalinity	Scale 0-20	ASTM D1121*		2.5	3.0	
	Percentage Glycol	%	ASTM D3321*		48.7	50.8	
	Freezing Point	°C	ASTM D3321*		-35	-35	
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		39	14	
	Phosphorus	ppm	ASTM D5185(m)		14	112	
	Boron	ppm	ASTM D5185(m)		216	21	
	Molybdenum	ppm	ASTM D5185(m)		0	36	
	Sodium	ppm	ASTM D5185(m)		1863	383	
	Potassium	ppm	ASTM D5185(m)		366	4087	
	Coolant Color		Visual*		Green	Grn/Yellow	





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

: WC0890738 Lab Number : 02616799 Unique Number : 5733909

Received **Tested** Diagnosed : 20 Feb 2024


: 22 Feb 2024

: 22 Feb 2024 - Kevin Marson

Test Package : COOL ( Additional Tests: GlycolType )

Dec16/22 -

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.



7367 Wellington Rd. 30, Unit A Guelph, ON CA NOM 2TO

Contact: CG Equipment CG Guelph cory@cgequipment.com T: (519)826-0550

F: (519)837-2055