MOB POWERStation POWER GENERATION PRODUCTS

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
[84404]
Machine Id
115 SCARSDALE RD TORONTO, UNIT #4 BELL CANADA 95030500180
Component
Rear Diesel Engine
Fluid
ESSO XD-3 EXTRA 15W40 (320 LTR)

RECOMMENDATION

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. this testkit includes BN to determine the suitability of the oil for continued use.

WEAR

Metal levels are typical for a new component breaking in. Component wear rates appear to be normal (unconfirmed).

CONTAMINATION

There is no indication of any contamination in the oil.

FLUID CONDITION

The condition of the oil is acceptable for the time in service (unconfirmed).

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0005361	PN0004433	PN0001960
Sample Date		Client Info		12 Feb 2024	07 Feb 2023	15 Feb 2022
Machine Age	hrs	Client Info		904	816	753
Oil Age	hrs	Client Info		90	62	0
Filter Age	hrs	Client Info		90	62	0
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
Iron	ppm	ASTM D5185(m)	>100	3	5	4
Chromium	ppm	ASTM D5185(m)	>20	<1	0	<1
Nickel	ppm	ASTM D5185(m)	>4	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	<1	0
Silver	ppm	ASTM D5185(m)	>3	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	2	3	2
Lead	ppm	ASTM D5185(m)	>40	0	0	0
Copper	ppm	ASTM D5185(m)	>330	2	3	3
Tin	ppm	ASTM D5185(m)	>15	0	<1	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Silicon	ppm	ASTM D5185(m)	>25	2	4	3
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	6.8	8.0	9.2
Sulfation	Abs/.1mm	ASTM D7415*	>30	20.2	19.7	20.9
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Sodium	ppm	ASTM D5185(m)	>192	2	3	3
Boron	ppm	ASTM D5185(m)		125	74	66
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		86	97	86
Manganese	ppm	ASTM D5185(m)		0	<1	0
Magnesium	ppm	ASTM D5185(m)		766	120	125
Calcium	ppm	ASTM D5185(m)	3780	1410	2452	2230
Phosphorus	ppm	ASTM D5185(m)	1370	921	1197	1060
Zinc	ppm	ASTM D5185(m)	1500	1058	1289	1270
Sulfur	ppm	ASTM D5185(m)	3800	2659	3347	3297
Oxidation	Abs/.1mm	ASTM D7414*	>25	15.1	13.9	16.8
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	13.2	14.7	14.4



















ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PN0005361 **Received** : 21 Feb 2024
Lab Number : 02616829 **Tested** : 21 Feb 2024
Unique Number : 5733939 **Diagnosed** : 21 Feb 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: Visual)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.
1050 JAYSON COURT
MISSISSAUGA, ON
CA L4W 2V5
Contact: Brett Kinkley
Bkinkley@pwrstn.com
T:
F: (905)565-8544