POWER GENERATION PRODUCTS

OIL ANALYSIS REPORT

[84385] Machine Id 115 SCARSDALE RD, TORONTO, UNIT #3 BELL CANADA 95030500179

Left Diesel Engine

ESSO XD-3 EXTRA 15W40 (320 LTR)

RECOMMENDATION

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. this testkit includes BN to determine the suitability of the oil for continued use.

WEAR

Metal levels are typical for a new component breaking in. Component wear rates appear to be normal (unconfirmed).

CONTAMINATION


There is no indication of any contamination in the oil.


FLUID CONDITION

The condition of the oil is acceptable for the time in service (unconfirmed).

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0005730	PN0000807	
Sample Date		Client Info		13 Feb 2024	20 Dec 2019	
Machine Age	hrs	Client Info		927	598	
Oil Age	hrs	Client Info		93	0	
Filter Age	hrs	Client Info		93	0	
Oil Changed		Client Info		Changed	Not Changd	
Filter Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	NORMAL	
Iron	ppm	ASTM D5185(m)	>100	3	4	
Chromium	ppm	ASTM D5185(m)	>20	0	<1	
Nickel	ppm	ASTM D5185(m)	>4	0	0	
Titanium	ppm	ASTM D5185(m)		0	<1	
Silver	ppm	ASTM D5185(m)	>3	0	0	
Aluminum	ppm	ASTM D5185(m)	>20	3	1	
Lead	ppm	ASTM D5185(m)	>40	<1	0	
Copper	ppm	ASTM D5185(m)	>330	2	3	
Tin	ppm	ASTM D5185(m)	>15	0	<1	
Vanadium	ppm	ASTM D5185(m)		0	0	
Silicon	ppm	ASTM D5185(m)	>25	3	2	
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	
Fuel	pp	WC Method	>5	<1.0	0.9	
Water		WC Method	>0.2	NEG	NEG	
Glycol		WC Method		NEG	NEG	
Soot %	%	ASTM D7844*	>3	0	0	
Nitration	Abs/cm	ASTM D7624*	>20	7.8	7.4	
Sulfation	Abs/.1mm	ASTM D7415*	>30	19.8	26.1	
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	
Sodium	ppm	ASTM D5185(m)	>192	1	2	
Boron	ppm	ASTM D5185(m)		122	49	
Barium	ppm	ASTM D5185(m)		0	<1	
Molybdenum	ppm	ASTM D5185(m)		62	42	
Manganese	ppm	ASTM D5185(m)		0	<1	
Magnesium	ppm	ASTM D5185(m)		430	549	
Calcium	ppm	ASTM D5185(m)	3780	1837	1755	
Phosphorus	ppm	ASTM D5185(m)	1370	982	795	
Zinc	ppm	ASTM D5185(m)	1500	1094	940	
Sulfur	ppm	ASTM D5185(m)	3800	2991	2212	
Oxidation	Abs/.1mm	ASTM D7414*	>25	15.2	21.2	
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	14.1	13.0	

Contact/Location: Ryan Udall - POWMIS





Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. Received : 21 Feb 2024 : PN0005730 Lab Number : 02616980 Tested : 22 Feb 2024 ISO 17025:2017 Accredited Laboratory Diagnosed Unique Number : 5734090 : 22 Feb 2024 - Wes Davis Test Package : MOB 1 To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Ryan Udall rudall@pwrstn.com T: (905)565-1621 F: (905)629-1499

Contact/Location: Ryan Udall - POWMIS

Page 2 of 2