



OIL ANALYSIS REPORT

| | |
|-----------------|---------------|
| WEAR | NORMAL |
| CONTAMINATION | NORMAL |
| FLUID CONDITION | NORMAL |

Area
MIANKI AIRCRAFT REPAIR SERVICE [52986]
 Machine Id
DEHAVILLAND DHC3T P-35094C (S/N 239)
 Component
Jet Turbine
 Fluid
BP TURBO OIL 2380 (--- GAL)

RECOMMENDATION

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number | | Client Info | | GT56904 | GT56912 | GT52574 |
| Sample Date | | Client Info | | 17 Jan 2024 | 21 Aug 2023 | 13 Jun 2023 |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | | 356 | 300 | 100 |
| Filter Age | hrs | Client Info | | 33 | 100 | 100 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Filter Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | --- | --- | --- |

WEAR







| | | | | | | |
|----------|-----|---------------|----|----------|----|---|
| Iron | ppm | ASTM D5185(m) | >8 | 0 | 0 | 0 |
| Chromium | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >2 | 1 | 1 | 1 |
| Lead | ppm | ASTM D5185(m) | >3 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185(m) | >3 | 0 | <1 | 0 |

CONTAMINATION

| | | | | | | |
|-------|--|-----------|------|------------|-----|-----|
| Water | | WC Method | >0.1 | NEG | NEG | NEG |
|-------|--|-----------|------|------------|-----|-----|

FLUID CONDITION

| | | | | | | |
|------------------|----------|---------------|------|--------------|------|------|
| Magnesium | ppm | ASTM D5185(m) | 0 | <1 | <1 | 0 |
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.43 | 0.97 | 0.78 | 0.74 |



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : GT56904 **Received** : 21 Feb 2024
Lab Number : 02617331 **Tested** :
Unique Number : 5734441 **Diagnosed** :
Test Package : G331 (Additional Tests: ICP)

Honeywell Engines
 111 S. 34th Street, 301 Receiving, Attn: SOAP Program
 PHOENIX, AZ
 US 85034
 Contact: GARRETT

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: (602)365-2676