



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area  
**Shelter Pass**  
 Machine Id  
**KUBOTA V3800-T K0357 (S/N 2LJ0357)**  
 Component  
**Diesel Engine**  
 Fluid  
**MOBIL 15W40 (15 LTR)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0894257	---	---
Sample Date		Client Info		02 Feb 2024	---	---
Machine Age	hrs	Client Info		12500	---	---
Oil Age	hrs	Client Info		285	---	---
Filter Age	hrs	Client Info		285	---	---
Oil Changed		Client Info		Changed	---	---
Filter Changed		Client Info		Changed	---	---
Sample Status				NORMAL	---	---

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185(m)	>100	6	---	---
Chromium	ppm	ASTM D5185(m)	>20	0	---	---
Nickel	ppm	ASTM D5185(m)	>4	<1	---	---
Titanium	ppm	ASTM D5185(m)		0	---	---
Silver	ppm	ASTM D5185(m)	>3	0	---	---
Aluminum	ppm	ASTM D5185(m)	>20	2	---	---
Lead	ppm	ASTM D5185(m)	>40	<1	---	---
Copper	ppm	ASTM D5185(m)	>330	<1	---	---
Tin	ppm	ASTM D5185(m)	>15	0	---	---
Vanadium	ppm	ASTM D5185(m)		0	---	---

**CONTAMINATION**













There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	5	---	---
Potassium	ppm	ASTM D5185(m)	>20	<1	---	---
Fuel		WC Method	>5	<1.0	---	---
Water		WC Method	>0.2	NEG	---	---
Glycol		WC Method		NEG	---	---
Soot %	%	ASTM D7844*	>3	0.1	---	---
Nitration	Abs/cm	ASTM D7624*	>20	5.8	---	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	19.5	---	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---	---

**FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185(m)	>118	<1	---	---
Boron	ppm	ASTM D5185(m)		2	---	---
Barium	ppm	ASTM D5185(m)		0	---	---
Molybdenum	ppm	ASTM D5185(m)		59	---	---
Manganese	ppm	ASTM D5185(m)		0	---	---
Magnesium	ppm	ASTM D5185(m)		979	---	---
Calcium	ppm	ASTM D5185(m)		1048	---	---
Phosphorus	ppm	ASTM D5185(m)		1034	---	---
Zinc	ppm	ASTM D5185(m)		1172	---	---
Sulfur	ppm	ASTM D5185(m)		2851	---	---
Oxidation	Abs/.1mm	ASTM D7414*	>25	14.7	---	---
Base Number (BN)	mg KOH/g	ASTM D2896*		10.10	---	---
Visc @ 100°C	cSt	ASTM D7279(m)		12.8	---	---



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0894257  
**Lab Number** : 02617978  
**Unique Number** : 5735088  
**Test Package** : MOB 2  
**Received** : 26 Feb 2024  
**Tested** : 26 Feb 2024  
**Diagnosed** : 26 Feb 2024 - Wes Davis

**Mowi Canada West**  
 7200 Coho Road  
 Port Hardy, BC  
 CA V0N 2P0  
 Contact: Brian Dalton  
 brian.dalton@mowi.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: