WEAR
CONTAMINATION
FLUID CONDITION

NORMAL SEVERE ABNORMAL

Area [84549]

## 20 CORK ST, GUELPH BELL CANADA 5362004816

Right Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
We advise that you check the fuel injection system. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.	Sample Number		Client Info		PN0005826	PN0004467	PN000158
	Sample Date		Client Info		22 Feb 2024	07 Mar 2023	28 Sep 202
	Machine Age	hrs	Client Info		366	352	285
	Oil Age	hrs	Client Info		13	0	22
	Filter Age	hrs	Client Info		13	0	22
	Oil Changed		Client Info		Not Changd	Changed	Not Chang
	Filter Changed		Client Info		Changed	Changed	Not Chang
	Sample Status				SEVERE	ABNORMAL	ABNORMA
WEAR	Iron	nnm	ACTM DE10E/m)	. 100	4	Л	2
WEAR  Metal levels are typical for a new component breaking in.	Iron	ppm	ASTM D5185(m)		4	4	2
	Chromium	ppm	ASTM D5185(m)		<1	0	<1 0
	Nickel Titanium	ppm	ASTM D5185(m) ASTM D5185(m)	24	<1 0	<1	<1
	Silver	ppm	ASTM D5185(m)	>3	0	0	0
	Aluminum	ppm	ASTM D5185(m)		2	2	<1
	Lead	ppm	ASTM D5185(m)		3	2	1
	Copper	ppm	ASTM D5185(m)		5	4	2
	Tin	ppm	ASTM D5185(m)		<1	<1	<1
	Vanadium	ppm	ASTM D5185(m)		0	0	0
CONTAMINATION							
CONTAMINATION	Silicon	ppm	ASTM D5185(m)		4	3	3
There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.	Potassium	ppm	ASTM D5185(m)	>20	1	<1	<1
	Fuel	%	ASTM D7593*	>5	▲ 8.4	▲ 6.1	▲ 5.3
	Water		WC Method WC Method	>0.2	NEG NEG	NEG NEG	NEG NEG
	Glycol Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7644  ASTM D7624*	>20	7.1	7.3	5.8
	Sulfation	Abs/.1mm	ASTM D7024 ASTM D7415*	>30	19.7	22.3	20.6
	Emulsified Water		Visual*	>0.2	NEG	NEG	NEG
THIR CONDITION							
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)		4	5	4
The oil is no longer serviceable due to the presence of contaminants.	Boron	ppm	ASTM D5185(m)		44	51	54
	Barium	ppm	ASTM D5185(m)		0	0	0
	Monganas	ppm	ASTM D5185(m)		43	42	37
	Manganese Magnesium	ppm	ASTM D5185(m) ASTM D5185(m)		0 461	<1 417	<1 496
	Calcium	ppm	ASTM D5185(m)	3780	1573	1688	1552
	Phosphorus	ppm	ASTM D5185(m)		788	816	752
	Zinc	ppm	ASTM D5185(m)		866	853	860
	Sulfur	ppm	ASTM D5185(m)		2357	2230	2184
	Oxidation	Abs/.1mm	ASTM D7414*		19.1	19.4	18.6
				-		4.5.5	
	Visc @ 40°C	cSt	ASTM D7279(m)	116	<b>72.5</b>		

Visc @ 100°C cSt

ASTM D7279(m)

Viscosity Index (VI) Scale ASTM D2270\* 140


15.4

**10.8** 

137

10.9

<u>11.5</u>





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PN0005826

: 02618930 Unique Number : 5736040

Received **Tested** 

:01 Mar 2024 Diagnosed

: 01 Mar 2024 - Kevin Marson Test Package: MOB 1 (Additional Tests: KV40, PercentFuel, VI)

: 29 Feb 2024

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com

F: (905)565-8544

T: