



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area

**[84483]**

Machine Id

**5000 HWY 7 MARKHAM PHASE 1 CADILLAC FAIRVIEW D120328470**

Component

**Diesel Engine**

Fluid

**ESSO XD-3 EXTRA 15W40 (7 LTR)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>PN0005617</b>	PN0004476	PN0003280
Sample Date		Client Info		<b>20 Feb 2024</b>	21 Feb 2023	09 Feb 2022
Machine Age	hrs	Client Info		<b>216</b>	200	182
Oil Age	hrs	Client Info		<b>16</b>	20	0
Filter Age	hrs	Client Info		<b>16</b>	20	0
Oil Changed		Client Info		<b>Changed</b>	Changed	Changed
Filter Changed		Client Info		<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	NORMAL	ABNORMAL

**WEAR**

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>90	<b>4</b>	4	3
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>2	<b>2</b>	2	2
Titanium	ppm	ASTM D5185(m)	>2	<b>0</b>	<1	0
Silver	ppm	ASTM D5185(m)	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>2</b>	3	3
Lead	ppm	ASTM D5185(m)	>40	<b>&lt;1</b>	<1	1
Copper	ppm	ASTM D5185(m)	>330	<b>4</b>	4	4
Tin	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0

**CONTAMINATION**











There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	<b>6</b>	9	9
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	0
Fuel		WC Method	>3.0	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	0.0
Soot %	%	ASTM D7844*	>6	<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>7.0</b>	7.4	8.5
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>17.2</b>	19.4	17.0
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	▲ .2%

**FLUID CONDITION**

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	<b>3</b>	4	3
Boron	ppm	ASTM D5185(m)		<b>44</b>	65	72
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>50</b>	87	86
Manganese	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)		<b>387</b>	30	56
Calcium	ppm	ASTM D5185(m)	3780	<b>1738</b>	2242	2069
Phosphorus	ppm	ASTM D5185(m)	1370	<b>1017</b>	1105	1065
Zinc	ppm	ASTM D5185(m)	1500	<b>1118</b>	1139	1148
Sulfur	ppm	ASTM D5185(m)	3800	<b>3182</b>	3275	3276
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>12.8</b>	11.9	13.0
Visc @ 40°C	cSt	ASTM D7279(m)	116	<b>97.2</b>	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<b>13.6</b>	14.0	21.0
Viscosity Index (VI)	Scale	ASTM D2270*	140	<b>140</b>	---	---



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PN0005617 **Received** : 29 Feb 2024  
**Lab Number** : 02618936 **Tested** : 29 Feb 2024  
**Unique Number** : 5736046 **Diagnosed** : 29 Feb 2024 - Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: KV40, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**POWER STATION INC.**  
 1050 JAYSON COURT  
 MISSISSAUGA, ON  
 CA L4W 2V5  
 Contact: Brett Kinkley  
 Bkinkley@pwrstn.com  
 T:  
 F: (905)565-8544