



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Machine Id

C-71

Component

Coolant

Fluid

EXTENDED LIFE COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service. Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		CU0021079	---	---
Sample Date		Client Info		21 Feb 2024	---	---
Machine Age	hrs	Client Info		5602	---	---
Oil Age	hrs	Client Info		250	---	---
Oil Changed		Client Info		Not Chngd	---	---
Sample Status				NORMAL	---	---

CORROSION

All metal levels are normal indicating no corrosion in the cooling system.

Iron	ppm	ASTM D5185(m)	>15	0	---	---
Aluminum	ppm	ASTM D5185(m)	>10	0	---	---
Copper	ppm	ASTM D5185(m)	>10	0	---	---
Lead	ppm	ASTM D5185(m)	>10	<1	---	---
Tin	ppm	ASTM D5185(m)	>10	0	---	---
Silver	ppm	ASTM D5185(m)	>10	<1	---	---
Zinc	ppm	ASTM D5185(m)	>10	<1	---	---

CONTAMINANTS







There is no indication of any contamination in the coolant.

Calcium	ppm	ASTM D5185(m)	>100	5	---	---
Magnesium	ppm	ASTM D5185(m)	>40	2	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Coolant Appearance		Visual*	Clear	Clear	---	---

COOLANT CONDITION

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

Specific Gravity		ASTM D1298*		1.062	---	---
pH	Scale 0-14	ASTM D1287*	9.0	7.92	---	---
Nitrites	ppm	Alcan Test Kit*		1800	---	---
Reserve Alkalinity	Scale 0-20	ASTM D1121*		3.7	---	---
Percentage Glycol	%	ASTM D3321*	50	45.7	---	---
Freezing Point	°C	ASTM D3321*	-40	-31	---	---
Carboxylate				---	---	---
Silicon	ppm	ASTM D5185(m)		26	---	---
Phosphorus	ppm	ASTM D5185(m)		14	---	---
Boron	ppm	ASTM D5185(m)		390	---	---
Molybdenum	ppm	ASTM D5185(m)		35	---	---
Sodium	ppm	ASTM D5185(m)		7681	---	---
Potassium	ppm	ASTM D5185(m)		46	---	---
Coolant Color		Visual*	Orange/R	Red	---	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : CU0021079
Lab Number : 02619085
Unique Number : 5736195
Test Package : COOL (Additional Tests: GlycolType)

Received : 29 Feb 2024
Tested : 29 Feb 2024
Diagnosed : 01 Mar 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

FRANCOIS JUNEAU
 6135 PL MONTPELIER
 ORLEANS, ON
 CA K1W 1J1
 Contact: Francois Juneau
 francoisjuneau@hotmail.com
 T: (613)619-1256
 F: