WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL

Machine Id

**24 MAIN** 

Component Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor. Please specify the component make and model with your next sample.	Sample Number		Client Info		WC0897608		
	Sample Date		Client Info		22 Feb 2024		
	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				NORMAL		
VEAR	Iron	nnm	ACTM DE10E(m)	. 100	2		
VEAN	Iron	ppm	ASTM D5185(m)		3		
All component wear rates are normal.	Chromium Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m) ASTM D5185(m)	>4	<1		
	Silver	ppm	ASTM D5185(III) ASTM D5185(m)	. 0	0		
	Aluminum	ppm	ASTM D5185(m)		2		
	Lead	ppm	ASTM D5185(m)		2		
	Copper	ppm	ASTM D5185(m)		7		
	Tin	ppm	ASTM D5185(m)		, <1		
	Vanadium	ppm	ASTM D5185(m)	710	0		
	·····		7.01111 20100(111)				
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	4		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1		
	Fuel		WC Method	>5	<1.0		
	Water		WC Method	>0.2	NEG		
	Glycol		WC Method		NEG		
	Soot %	%	ASTM D7844*	>3	0		
	Nitration	Abs/cm	ASTM D7624*	>20	3.3		
	Sulfation	Abs/.1mm	ASTM D7415*	>30	13.1		
	Emulsified Water	scalar	Visual*	>0.2	NEG		
LUID CONDITION	Sodium	ppm	ASTM D5185(m)		2		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)	1	2		
	Barium	ppm	ASTM D5185(m)		0		
	Molybdenum	ppm	ASTM D5185(m)		109		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)	10	61		
	Calcium	ppm	ASTM D5185(m)	3032	2546		
	Phosphorus	ppm	ASTM D5185(m)	1054	1017		
	Zinc	ppm	ASTM D5185(m)	1332	1077		
	Sulfur	ppm	ASTM D5185(m)	3985	2864		
	Oxidation	Abs/.1mm	ASTM D7414*		6.2		
	Visc @ 100°C	cSt	ASTM D7279(m)		13.3		





CALA ISO 17025:2017 Accredited

Laboratory Sample No.

: WC0897608 Lab Number : 02619214

Unique Number : 5736324 Test Package : MOB 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received **Tested** 

Diagnosed

: 01 Mar 2024 : 01 Mar 2024 : 01 Mar 2024 - Wes Davis

80 ASHBRIDGE CIRCLE,, UNIT #1 & 2 WOODBRIDGE, ON

CA L4L 3R5 Contact: Selome Afework selome@northerngenerator.com

NORTHERN GENERATOR CO. LTD.

T: (905)264-9744 F: (905)264-9714

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.