WEAR CONTAMINATION **FLUID CONDITION** **NORMAL NORMAL NORMAL**

Machine Id

10 MARTHA EATON WAY

Component Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor. Please specify the component make and model with your next sample.	Sample Number		Client Info		WC0897604		
	Sample Date		Client Info		14 Feb 2024		
	Machine Age	hrs	Client Info		32		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				NORMAL		
VEAR	Iron	ppm	ASTM D5185(m)	>100	3		
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)		0		
	Nickel	ppm	ASTM D5185(m)		<1		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)	>3	0		
	Aluminum	ppm	ASTM D5185(m)	>20	1		
	Lead	ppm	ASTM D5185(m)	>40	<1		
	Copper	ppm	ASTM D5185(m)	>330	7		
	Tin	ppm	ASTM D5185(m)	>15	0		
	Vanadium	ppm	ASTM D5185(m)		0		
CONTAMINATION	0:1:		AOTH DELOC	05			
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	6		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)		1		
	Fuel		WC Method		<1.0		
	Water		WC Method	>0.2	NEG		
	Glycol	0/	WC Method	0	NEG		
	Soot % Nitration	%	ASTM D7844*		0 4.7		
	Sulfation	Abs/.1mm	ASTM D7624*	>20			
	Emulsified Water	scalar	ASTM D7415* Visual*	>30	18.2 NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)		2		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)	1	1		
	Barium	ppm	ASTM D5185(m)	1	2		
	Molybdenum	ppm	ASTM D5185(m)	1	56		
	Manganese	ppm	ASTM D5185(m)		<1		
	Magnesium	ppm	ASTM D5185(m)	10	966		
	Calcium	ppm	ASTM D5185(m)	3032	1042		
	Phosphorus	ppm	ASTM D5185(m)	1054	1047		
	Zinc	ppm	ASTM D5185(m)	1332	1159		
	Sulfur	ppm	ASTM D5185(m)	3985	2907		
	Oxidation	Abs/.1mm	ASTM D7414*	>25	13.3		
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	13.5		





CALA ISO 17025:2017 Accredited

Laboratory Sample No.

: WC0897604 Lab Number : 02619238 Unique Number : 5736348 Test Package : MOB 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 01 Mar 2024 **Tested** Diagnosed

: 01 Mar 2024 : 01 Mar 2024 - Wes Davis

NORTHERN GENERATOR CO. LTD. 80 ASHBRIDGE CIRCLE,, UNIT #1 & 2 WOODBRIDGE, ON

CA L4L 3R5 Contact: Selome Afework selome@northerngenerator.com

> T: (905)264-9744 F: (905)264-9714

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.