



WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
8308 BATHURST TORONTO 407 ETR 3002500722

Component
Rear Diesel Engine

Fluid
ESSO XD-3 EXTRA 15W40 (20 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0005895	PN0004704	PN0003350
Sample Date		Client Info		04 Mar 2024	06 Apr 2023	14 Mar 2022
Machine Age	hrs	Client Info		117	111	83
Oil Age	hrs	Client Info		6	0	5
Filter Age	hrs	Client Info		6	0	5
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>100	2	3	3
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>4	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	<1	0
Silver	ppm	ASTM D5185(m)	>3	0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	1	3	3
Lead	ppm	ASTM D5185(m)	>40	<1	0	<1
Copper	ppm	ASTM D5185(m)	>330	2	4	5
Tin	ppm	ASTM D5185(m)	>15	0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0

CONTAMINATION










There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	8	14	15
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	5.3	7.6	4.9
Sulfation	Abs/.1mm	ASTM D7415*	>30	18.0	17.2	15.5
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG

FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	2	2	3
Boron	ppm	ASTM D5185(m)		16	72	74
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		63	85	79
Manganese	ppm	ASTM D5185(m)		<1	3	6
Magnesium	ppm	ASTM D5185(m)		739	29	87
Calcium	ppm	ASTM D5185(m)	3780	1282	2217	2110
Phosphorus	ppm	ASTM D5185(m)	1370	1018	1094	1016
Zinc	ppm	ASTM D5185(m)	1500	1145	1156	1149
Sulfur	ppm	ASTM D5185(m)	3800	2871	3293	3157
Oxidation	Abs/.1mm	ASTM D7414*	>25	13.8	13.4	9.1
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	15.0	14.4	14.6



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PN0005895
Lab Number : 02620452
Unique Number : 5737562
Test Package : MOB 1
Received : 07 Mar 2024
Tested : 07 Mar 2024
Diagnosed : 07 Mar 2024 - Wes Davis

POWER STATION INC.
 1050 JAYSON COURT
 MISSISSAUGA, ON
 CA L4W 2V5
 Contact: Brett Kinkley
 Bkinkley@pwrstn.com
 T:
 F: (905)565-8544

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.