WEAR
CONTAMINATION
FLUID CONDITION

NORMAL NORMAL ABNORMAL

Machine Id

## 360 Bayview Pkwy N/A NEWMARKET SPS PRH05698

Left Diesel Engine

ESSO XD-3 EXTRA 15W40 (100 LTR)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. No other corrective action is recommended at this time.	Sample Number		Client Info		PN0005804		
	Sample Date		Client Info		05 Mar 2024		
	Machine Age	hrs	Client Info		241		
	Oil Age	hrs	Client Info		24		
	Filter Age	hrs	Client Info		24		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				ABNORMAL		
WEAR	Iron	ppm	ASTM D5185(m)	>100	7		
	Chromium	ppm	ASTM D5185(m)		<1		
Metal levels are typical for a new component breaking in.	Nickel	ppm	ASTM D5185(m)		1		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)	>25	1		
	Lead	ppm	ASTM D5185(m)	>40	<1		
	Copper	ppm	ASTM D5185(m)	>330	3		
	Tin	ppm	ASTM D5185(m)	>15	<1		
	Vanadium	ppm	ASTM D5185(m)		0		
CONTAMINATION			40714854054				
CONTAMINATION	Silicon	ppm	ASTM D5185(m)		15		
Light fuel dilution occurring. No other contaminants were detected in the oil.	Potassium	ppm	ASTM D5185(m)		1		
	Fuel	%	ASTM D7593*	>5	1.6		
	Water		WC Method	>0.2	NEG NEG		
	Glycol Soot %	%	WC Method ASTM D7844*	~ 2	0		
	Nitration	Abs/cm	ASTM D7644*	>20	6.1		
	Sulfation	Abs/.1mm	ASTM D7024 ASTM D7415*	>30	21.6		
	Emulsified Water		Visual*	>0.2	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	2		
Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		37		
	Barium	ppm	ASTM D5185(m)		0		
	Molybdenum	ppm	ASTM D5185(m)		36		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)		466		
	Calcium	ppm	ASTM D5185(m)	3780	1717		
	Phosphorus	ppm	ASTM D5185(m)	1370	924		
	Zinc	ppm	ASTM D5185(m)	1500	1040		
	Sulfur	ppm	ASTM D5185(m)		2655		
	Oxidation	Abs/.1mm	ASTM D7414*		19.3		
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<u> </u>		





CALA
Terry
Acceptation 1: 100:011

ISO 17025:2017
Accredited

**Laboratory**: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Sample No.**: PN0005804 **Received**: 07 Mar 2024

 Lab Number
 : 02620456
 Tested
 : 08 Mar 2024

 Accredited Laboratory
 Unique Number
 : 5737566
 Diagnosed
 : 08 Mar 2024 - Kevin Marson

Test Package : MOB 1 ( Additional Tests: FuelDilution, PercentFuel )

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Ryan Udall rudall@pwrstn.com T: (905)565-1621

F: (905)629-1499