



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Machine Id  
**6897 Financial Dr. Mississauga QUADREAL PE5030H159990**

Component  
**Left Diesel Engine**

Fluid  
**ESSO XD-3 EXTRA 15W40 (12 LTR)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>PN0005900</b>	---	---
Sample Date		Client Info		<b>02 Mar 2024</b>	---	---
Machine Age	hrs	Client Info		<b>225</b>	---	---
Oil Age	hrs	Client Info		<b>0</b>	---	---
Filter Age	hrs	Client Info		<b>0</b>	---	---
Oil Changed		Client Info		<b>Changed</b>	---	---
Filter Changed		Client Info		<b>Changed</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

**WEAR**

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>51	<b>2</b>	---	---
Chromium	ppm	ASTM D5185(m)	>11	<b>0</b>	---	---
Nickel	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Silver	ppm	ASTM D5185(m)	>3	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185(m)	>31	<b>2</b>	---	---
Lead	ppm	ASTM D5185(m)	>26	<b>0</b>	---	---
Copper	ppm	ASTM D5185(m)	>26	<b>&lt;1</b>	---	---
Tin	ppm	ASTM D5185(m)	>4	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	---	---
White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---

**CONTAMINATION**










There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>22	<b>8</b>	---	---
Potassium	ppm	ASTM D5185(m)	>20	<b>1</b>	---	---
Fuel		WC Method	>2.1	<b>&lt;1.0</b>	---	---
Water		WC Method	>0.21	<b>NEG</b>	---	---
Glycol		WC Method		<b>NEG</b>	---	---
Soot %	%	ASTM D7844*	>3	<b>0</b>	---	---
Nitration	Abs/cm	ASTM D7624*	>20	<b>4.8</b>	---	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>20.2</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	Visual*	>0.21	<b>NEG</b>	---	---

**FLUID CONDITION**

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	<b>2</b>	---	---
Boron	ppm	ASTM D5185(m)		<b>351</b>	---	---
Barium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185(m)		<b>74</b>	---	---
Manganese	ppm	ASTM D5185(m)		<b>0</b>	---	---
Magnesium	ppm	ASTM D5185(m)		<b>408</b>	---	---
Calcium	ppm	ASTM D5185(m)	3780	<b>1418</b>	---	---
Phosphorus	ppm	ASTM D5185(m)	1370	<b>1022</b>	---	---
Zinc	ppm	ASTM D5185(m)	1500	<b>1154</b>	---	---
Sulfur	ppm	ASTM D5185(m)	3800	<b>2985</b>	---	---
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>14.3</b>	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<b>13.9</b>	---	---



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PN0005900 **Received** : 07 Mar 2024  
**Lab Number** : 02620490 **Tested** : 07 Mar 2024  
**Unique Number** : 5737600 **Diagnosed** : 07 Mar 2024 - Kevin Marson  
**Test Package** : MOB 1 ( Additional Tests: Visual )

**POWER STATION INC.**  
 1050 JAYSON COURT  
 MISSISSAUGA, ON  
 CA L4W 2V5  
 Contact: Ryan Udall  
 rudall@pwrstn.com  
 T: (905)565-1621  
 F: (905)629-1499

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.