

CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL




TRANSMISSION/TULLAMORE

IGZ07555

Component Coolant

EXTENDED LIFE COOLANT (LTR)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service. Resample at the next service interval to monitor.	Sample Number		Client Info		WC0867591	WC0323818	
	Sample Date		Client Info		14 Mar 2024	15 Jul 2019	
	Machine Age	hrs	Client Info		675	447	
	Oil Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		Not Changd	Not Changd	
	Sample Status				NORMAL	NORMAL	
CORROSION	Iron	ppm	ASTM D5185(m)	>15	0	0	
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D5185(m)	>10	4	3	
	Copper	ppm	ASTM D5185(m)	>10	<1	0	
	Lead	ppm	ASTM D5185(m)	>10	0	0	
	Tin	ppm	ASTM D5185(m)	>10	0	0	
	Silver	ppm	ASTM D5185(m)	>10	2	0	
	Zinc	ppm	ASTM D5185(m)	>10	4	1	
CONTAMINANTS	Calcium	ppm	ASTM D5185(m)	>100	11	4	
There is no indication of any contamination in the coolant.	Magnesium	ppm	ASTM D5185(m)	>40	4	1	
	Appearance	scalar	Visual*	NORML	NORML	NORML	
	Odor	scalar	Visual*	NORML	NORML	NORML	
	Coolant Appearance		Visual*	Clear	Clear	Clear	
COOLANT CONDITION	Boiling Point	°C	WC Method*		107		
The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.	Specific Gravity		ASTM D1298*		1.065	1.064	
	рН	Scale 0-14	ASTM D1287*	9.0	8.00	8.27	
	Nitrites	ppm	Alcan Test Kit*		640	600	
	Reserve Alkalinity	Scale 0-20	ASTM D1121*		3.8	3.7	
	Percentage Glycol		ASTM D3321*	50	48.7	47.0	
	Freezing Point	°C	ASTM D3321*	-40	-35	-33	
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		10	8	
	Phosphorus	ppm	ASTM D5185(m)		7	64	
	Boron	ppm	ASTM D5185(m)		26	13	
	Molybdenum	ppm	ASTM D5185(m)		588	620	
	Sodium	ppm	ASTM D5185(m) ASTM D5185(m)		5709	3067	
	Potassium Coolant Color	ppm	Visual*	Orange/R	33 Red	179 Red	
	Coolant Color		visudi	Orange/K	neu	neu	





CALA ISO 17025:2017 Accredited Laboratory

Sample No.

Laboratory

Lab Number : 02625059

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0867591

Unique Number : 5750178

Received **Tested** Diagnosed : 27 Mar 2024

: 27 Mar 2024

: 28 Mar 2024 - Kevin Marson

Test Package: COOL (Additional Tests: GlycolType) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

ONTARIO CLEAN WATER AGENCY

920 EAST AVENUE MISSISSAUGA, ON **CA L5E 1W6** Contact: Kevin Ho

kho@ocwa.com T: (905)301-6482 F: (905)274-5906