

CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL



TRANSMISSION/WEST BRAMPTON

260751 (S/N EBG00646)

Component Coolant

CAT EXTENDED LIFE COOLANT (ELC) (LTR)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service. Resample at the next service interval to monitor.	Sample Number		Client Info		WC0918931	WC0867727	
	Sample Date		Client Info		13 Mar 2024	05 Oct 2023	
	Machine Age	hrs	Client Info		622	0	
	Oil Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		N/A	N/A	
	Sample Status				NORMAL	NORMAL	
CORROSION	Iron	ppm	ASTM D5185(m)	>15	<1	0	
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D5185(m)	>10	4	2	
	Copper	ppm	ASTM D5185(m)	>10	1	<1	
	Lead	ppm	ASTM D5185(m)	>10	0	0	
	Tin	ppm	ASTM D5185(m)	>10	0	0	
	Silver	ppm	ASTM D5185(m)	>10	2	<1	
	Zinc	ppm	ASTM D5185(m)	>10	1	0	
CONTAMINANTS	Calcium	ppm	ASTM D5185(m)	>100	8	10	
There is no indication of any contamination in the coolant.	Magnesium	ppm	ASTM D5185(m)	>40	2	2	
	Appearance	scalar	Visual*	NORML	NORML	NORML	
	Odor	scalar	Visual*	NORML	NORML	NORML	
	Coolant Appearance		Visual*	Clear	Clear	Clear	
COOLANT CONDITION	Boiling Point	°C	WC Method*		107		
The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.	Specific Gravity		ASTM D1298*	1.070	1.064	1.063	
	рН	Scale 0-14	ASTM D1287*	8.3	7.96	7.99	
	Nitrites	ppm	Alcan Test Kit*	550	640	800	
	Reserve Alkalinity	Scale 0-20	ASTM D1121*	5.5	3.7	6.4	
	Percentage Glycol	%	ASTM D3321*	50	47.0	46.8	
	Freezing Point	°C	ASTM D3321*	-37	-33	-26	
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		9	12	
	Phosphorus	ppm	ASTM D5185(m)		254	71	
	Boron	ppm	ASTM D5185(m)		18	25	
	Molybdenum	ppm	, ,	950	554	513	
	Sodium	ppm	ASTM D5185(m)		5491	5358	
	Potassium	ppm	ASTM D5185(m)	D .	884	584	
	Coolant Color		Visual*	Red	Red	Orange	





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

Lab Number : 02625060 Unique Number : 5750179

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0918931

Received **Tested** Diagnosed **Test Package**: COOL (Additional Tests: GlycolType)

: 27 Mar 2024 : 28 Mar 2024

: 28 Mar 2024 - Kevin Marson

920 EAST AVENUE MISSISSAUGA, ON **CA L5E 1W6** Contact: Kevin Ho kho@ocwa.com T: (905)301-6482 F: (905)274-5906

ONTARIO CLEAN WATER AGENCY

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

Report Id: MINMIS [WCAMIS] 02625060 (Generated: 03/28/2024 09:23:06) Rev: 1

Contact/Location: Transmission - Kevin Ho - MINMIS