



Machine Id  
**731091**  
Component  
**Natural Gas Engine**  
Fluid  
**PETRO CANADA DURON GEO LD 15W40 (--- LTR)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>GFL0117144</b>	GFL0085885	GFL0085849
Sample Date		Client Info		<b>02 Apr 2024</b>	06 Sep 2023	04 Aug 2023
Machine Age	kms	Client Info		<b>59917</b>	4565	4388
Oil Age	kms	Client Info		<b>0</b>	1200	1200
Filter Age	kms	Client Info		<b>0</b>	1200	1200
Oil Changed		Client Info		<b>Changed</b>	Changed	Changed
Filter Changed		Client Info		<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>50	<b>12</b>	6	13
Chromium	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	1
Nickel	ppm	ASTM D5185(m)	>2	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185(m)	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>9	<b>2</b>	1	2
Lead	ppm	ASTM D5185(m)	>30	<b>1</b>	<1	9
Copper	ppm	ASTM D5185(m)	>35	<b>2</b>	1	1
Tin	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0

**CONTAMINATION**











There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>+100	<b>2</b>	4	4
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>12.0</b>	8.2	12.8
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>24.3</b>	21.0	26.4
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)		<b>7</b>	5	9
Boron	ppm	ASTM D5185(m)	50	<b>8</b>	33	8
Barium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	50	<b>54</b>	52	58
Manganese	ppm	ASTM D5185(m)	0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	560	<b>572</b>	585	624
Calcium	ppm	ASTM D5185(m)	1510	<b>1608</b>	1456	1669
Phosphorus	ppm	ASTM D5185(m)	780	<b>659</b>	770	784
Zinc	ppm	ASTM D5185(m)	870	<b>924</b>	884	976
Sulfur	ppm	ASTM D5185(m)	2040	<b>1955</b>	2051	2093
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>19.2</b>	15.9	20.8
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	<b>14.3</b>	13.7	14.2



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : GFL0117144  
**Lab Number** : 02626849  
**Unique Number** : 5759981  
**Test Package** : MOB 1  
**Received** : 05 Apr 2024  
**Tested** : 05 Apr 2024  
**Diagnosed** : 05 Apr 2024 - Wes Davis

**GFL Environmental - 209 - Hamilton**  
 560 Seaman Street  
 Stoney Creek, ON  
 CA L8E 3X7  
 Contact: Fred Carleton  
 fred.carleton@gflenv.com  
 T: (289)925-6693  
 F: (905)664-9008

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.