I POWER GENERATION PRODUCTS OIL ANALYSIS REPORT

Machine Id 81 WHISPER LANE KLEINBURG YORK REGION YORK REGION Component

Right Diesel Engine

ESSO XD-3 EXTRA 15W40 (40 LTR)

| RECOMMENDATION | |
|----------------|--|
|----------------|--|

The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

Metal levels are typical for a new component breaking in.

CONTAMINATION

Light fuel dilution occurring.

FLUID CONDITION

Fuel is present in the oil and is lowering the viscosity. The condition of the oil is acceptable for the time in service.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|------------------|--------------------------|---------------------------------------|-------------|------------------|----------|----------|
| Sample Number | | Client Info | | PN0005915 | | |
| Sample Date | | Client Info | | 08 Apr 2024 | | |
| Machine Age | hrs | Client Info | | 366 | | |
| Oil Age | hrs | Client Info | | 30 | | |
| Filter Age | hrs | Client Info | | 30 | | |
| Oil Changed | | Client Info | | Changed | | |
| Filter Changed | | Client Info | | Changed | | |
| Sample Status | | | | ABNORMAL | | |
| | | | | | | |
| Iron | ppm | ASTM D5185(m) | >200 | 4 | | |
| Chromium | ppm | ASTM D5185(m) | >10 | 0 | | |
| Nickel | ppm | ASTM D5185(m) | >4 | 0 | | |
| Titanium | ppm | ASTM D5185(m) | >2 | 0 | | |
| Silver | ppm | ASTM D5185(m) | >2 | 0 | | |
| Aluminum | ppm | ASTM D5185(m) | >30 | <1 | | |
| Lead | ppm | ASTM D5185(m) | >30 | <1 | | |
| Copper | ppm | ASTM D5185(m) | >30 | 2 | | |
| Tin | ppm | ASTM D5185(m) | >4 | <1 | | |
| Vanadium | ppm | ASTM D5185(m) | | 0 | | |
| Silicon | | ASTM D5185(m) | . 20 | 7 | | |
| Potassium | ppm | . , | >30 | - | | |
| Fuel | ppm % | ASTM D5185(m) ASTM D7593* | >20 >3.0 | <1 2.3 | | |
| Water | 70 | WC Method | | NEG | | |
| | | WC Method | >0.2 | NEG | | |
| Glycol Soot % | % | ASTM D7844* | >3 | 0 | | |
| Nitration | 7 _o Abs/cm | ASTM D7644 ASTM D7624* | >3 >20 | 5.9 | | |
| Sulfation | Abs/.1mm | ASTM D7624 ASTM D7415* | | | | |
| Emulsified Water | | Visual* | >30 | 22.4 | | |
| | scalar | • • • • • • • • • • • • • • • • • • • | >0.2 | NEG | | |
| Sodium | ppm | ASTM D5185(m) | >192 | 2 | | |
| Boron | ppm | ASTM D5185(m) | | 52 | | |
| Barium | ppm | ASTM D5185(m) | | 0 | | |
| Molybdenum | ppm | ASTM D5185(m) | | 37 | | |
| Manganese | ppm | ASTM D5185(m) | | <1 | | |
| Magnesium | ppm | ASTM D5185(m) | | 524 | | |
| Calcium | ppm | ASTM D5185(m) | 3780 | 1640 | | |
| Phosphorus | ppm | ASTM D5185(m) | 1370 | 912 | | |
| Zinc | ppm | ASTM D5185(m) | 1500 | 1056 | | |
| Sulfur | ppm | ASTM D5185(m) | 3800 | 2449 | | |
| Oxidation | Abs/.1mm | ASTM D7414* | >25 | 19.8 | | |
| Visc @ 100°C | cSt | ASTM D7279(m) | 15.4 | 10.8 | | |

Contact/Location: Brett Kinkley - POWMIS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 POWER STATION INC. CALA Sample No. 1050 JAYSON COURT : PN0005915 Received : 09 Apr 2024 j۳ Lab Number : 02627563 MISSISSAUGA, ON Tested : 10 Apr 2024 ISO 17025:2017 CA L4W 2V5 Accredited Unique Number : 5760695 Diagnosed : 10 Apr 2024 - Wes Davis Laboratory Test Package : MOB 1 (Additional Tests: FUELDILUTION, PercentFuel) Contact: Brett Kinkley To discuss this sample report, contact Customer Service at 1-800-268-2131. Bkinkley@pwrstn.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (905)565-8544 Validity of results and interpretation are based on the sample and information as supplied.

T:

Report Id: POWMIS [WCAMIS] 02627563 (Generated: 04/10/2024 09:28:13) Rev: 1