



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Machine Id
1673 - ORET PORTABLE #4 DIESEL PUMP

Component
Coolant
Fluid
CONVENTIONAL COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service. Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0896288	---	---
Sample Date		Client Info		16 Mar 2024	---	---
Machine Age	hrs	Client Info		0	---	---
Oil Age	hrs	Client Info		0	---	---
Oil Changed		Client Info		N/A	---	---
Sample Status				NORMAL	---	---

CORROSION

All metal levels are normal indicating no corrosion in the cooling system.

Iron	ppm	ASTM D5185(m)	>15	<1	---	---
Aluminum	ppm	ASTM D5185(m)	>10	<1	---	---
Copper	ppm	ASTM D5185(m)	>10	3	---	---
Lead	ppm	ASTM D5185(m)	>10	0	---	---
Tin	ppm	ASTM D5185(m)	>10	4	---	---
Silver	ppm	ASTM D5185(m)	>10	<1	---	---
Zinc	ppm	ASTM D5185(m)	>10	<1	---	---

CONTAMINANTS








There is no indication of any contamination in the coolant.

Calcium	ppm	ASTM D5185(m)	>100	1	---	---
Magnesium	ppm	ASTM D5185(m)	>40	<1	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Coolant Appearance		Visual*	Clear	Clear	---	---

COOLANT CONDITION

The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

Boiling Point	°C	WC Method*		107	---	---
Specific Gravity		ASTM D1298*		1.067	---	---
pH	Scale 0-14	ASTM D1287*	9.5	10.2	---	---
Nitrites	ppm	Alcan Test Kit*	1500	280	---	---
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	7.8	---	---
Percentage Glycol	%	ASTM D3321*	50	49.2	---	---
Freezing Point	°C	ASTM D3321*	-40	-36	---	---
Carboxylate				---	---	---
Silicon	ppm	ASTM D5185(m)		3	---	---
Phosphorus	ppm	ASTM D5185(m)		676	---	---
Boron	ppm	ASTM D5185(m)		11	---	---
Molybdenum	ppm	ASTM D5185(m)		<1	---	---
Sodium	ppm	ASTM D5185(m)		643	---	---
Potassium	ppm	ASTM D5185(m)		1843	---	---
Coolant Color		Visual*	Green	Green	---	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0896288 **Received** : 09 Apr 2024
Lab Number : 02627748 **Tested** : 09 Apr 2024
Unique Number : 5760880 **Diagnosed** : 10 Apr 2024 - Kevin Marson
Test Package : COOL (Additional Tests: GlycolType)

Lighthouse Electric
 6714 6th Conc South
 Amherstburg, ON
 CA N9V 0C8
 Contact: Brad Purdie
 brad_lighthouse@hotmail.com
 T: (519)730-1310
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.