

## Machine Id HL3111 AG1 (S/N 32065)

## 1 Auxiliary Engine

## PETRO CANADA BP ENERGOL DS3 153 (450 LTR)

	<u> </u>						
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		WC0807834	WC0807836	WC0807830
	Sample Date		Client Info		31 Mar 2024	02 Mar 2024	04 Feb 202
	Machine Age	hrs	Client Info		94019	93616	93245
	Oil Age	hrs	Client Info		0	0	0
	Filter Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		Not Changd	Not Changd	N/A
	Filter Changed		Client Info		Not Changd	Changed	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	PQ		ASTM D8184*		0	0	0
All component wear rates are normal.	Iron	ppm	ASTM D5185(m)	>35	7	7	8
	Chromium	ppm	ASTM D5185(m)	>4	0	0	0
	Nickel	ppm	ASTM D5185(m)	>2	<1	0	<1
	Titanium	ppm	ASTM D5185(m)	>2	0	0	0
	Silver	ppm	ASTM D5185(m)	>2	0	0	0
	Aluminum	ppm	ASTM D5185(m)	>25	1	<1	2
	Lead	ppm	ASTM D5185(m)	>7	0	0	0
	Copper	ppm	ASTM D5185(m)	>65	<1	<1	<1
	Tin	ppm	ASTM D5185(m)	>4	0	0	0
	Vanadium	ppm	ASTM D5185(m)		0	0	0
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>20	8	7	5
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
	Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
	Water		WC Method	>0.1	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>2	0.1	0.1	0.1
	Nitration	Abs/cm	ASTM D7624*	>20	10.3	10.0	10.3
	Sulfation	Abs/.1mm	ASTM D7415*	>30	16.0	15.8	16.2
	Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)		1	2	1
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185(m)		11	10	11
	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		<1	<1	1
	Manganese	ppm	ASTM D5185(m)		<1	0	0
	Magnesium	ppm	ASTM D5185(m)		35	37	35
	Calcium	ppm	ASTM D5185(m)		5585	5674	5473
	Phosphorus	ppm	ASTM D5185(m)		898	939	937
	Zinc	ppm	ASTM D5185(m)		1034	1084	1034
	Sulfur	ppm	ASTM D5185(m)		8805	9275	9385
						(	

Oxidation

Visc @ 100°C cSt

Abs/.1mm ASTM D7414\* >25

Base Number (BN) mg KOH/g ASTM D2896\* 15

ASTM D7279(m) 11.5 12.1 12.1 Contact/Location: Chief Engineer - CCGSHLAR

9.1

15.95


9.4

15.77

9.3

12.1

16.53



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : WC0807834 Received CCGS HENRY LARSEN, P.O. BOX 5667, 280 SOUTHSIDE RD. : 11 Apr 2024 Lab Number : 02628104 Tested ST. JOHN'S, NL : 12 Apr 2024 ISO 17025:2017 Accredited Unique Number : 5761236 : 12 Apr 2024 - Wes Davis CA A1C 5X1 Diagnosed Laboratory Test Package : MAR 2 (Additional Tests: PQ) Contact: Chief Engineer To discuss this sample report, contact Customer Service at 1-800-268-2131. henrylarsence@ccgs-ngcc.gc.ca T: (709)687-5198 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (709)685-3187 Validity of results and interpretation are based on the sample and information as supplied.

Contact/Location: Chief Engineer - CCGSHLAR Page 2 of 2