

## [142229] Machine Id KOHLER BASELINE SPS Component Coolant Fluid HYBRID (HOAT) COOLANT (15 LTR)

## RECOMMENDATION

The fluid is suitable for further service. Resample at the next service interval to monitor.

CO		-	
	 1		
		_	

All metal levels are normal indicating no corrosion in the cooling system.

## **CONTAMINANTS**

There is no indication of any contamination in the coolant.


.....


## COOLANT CONDITION

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0919625	WC0668148	WC106843
Sample Date		Client Info		10 Apr 2024	27 Apr 2022	08 Apr 2020
Machine Age	hrs	Client Info		0	0	67
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
Iron	ppm	ASTM D5185(m)	>15	0	<1	<1
Aluminum	ppm	ASTM D5185(m)	>10	<1	2	<1
Copper	ppm	ASTM D5185(m)	>10	<1	2	<1
Lead	ppm	ASTM D5185(m)	>10	0	<1	0
Tin	ppm	ASTM D5185(m)	>10	0	<1	<1
Silver	ppm	ASTM D5185(m)	>10	0	<1	0
Zinc	ppm	ASTM D5185(m)	>10	<1	1	0
Calcium	ppm	ASTM D5185(m)	>100	8	9	6
Magnesium	ppm	ASTM D5185(m)	>40	1	1	<1
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Coolant Appearance		Visual*	Clear		Clear	Clear
Boiling Point	°C	WC Method*		107		
Specific Gravity		ASTM D1298*		1.067	1.067	1.067
рН	Scale 0-14	ASTM D1287*		7.36	7.62	7.51
Nitrites	ppm	Alcan Test Kit*		1160	1560	1160
Reserve Alkalinity	Scale 0-20	ASTM D1121*		6.5	6.3	6.5
Percentage Glycol	%	ASTM D3321*		50.0	49.6	50.0
Freezing Point	°C	ASTM D3321*		-37	-33	-37
Carboxylate						
Silicon	ppm	ASTM D5185(m)		31	45	34
Phosphorus	ppm	ASTM D5185(m)		21	26	22
Boron	ppm	ASTM D5185(m)		1168	1136	1300
Molybdenum	ppm	ASTM D5185(m)		16	26	16
Sodium	ppm	ASTM D5185(m)		5771	2468	3759
Potassium	ppm	ASTM D5185(m)		311	391	369
Coolant Color		Visual*		[ ]	Yellow	Yellow

Contact/Location: Debbie Johnston - GENCOM Page 1 of 2





Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **GENREP LTD** CALA Sample No. : WC0919625 Received 476 HWY 77, R.R. # 3 : 15 Apr 2024 Lab Number : 02629052 Tested LEAMINGTON, ON : 17 Apr 2024 ISO 17025:2017 Accredited Laboratory Unique Number : 5762184 : 17 Apr 2024 - Kevin Marson CA N8H 3V6 Diagnosed Test Package : COOL (Additional Tests: GlycolType) Contact: Debbie Johnston To discuss this sample report, contact Customer Service at 1-800-268-2131. djohnston@genrep.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (519)325-0202 Validity of results and interpretation are based on the sample and information as supplied. F: (519)322-0026

Contact/Location: Debbie Johnston - GENCOM Page 2 of 2