CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL


[142229]

KOHLER WALLACE ST SPS

Component Coolant

HYBRID (HOAT) COOLANT (--- LTR)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service. Resample at the next service interval to monitor.	Sample Number	UOIVI	Client Info	LIIIII/ADII	WC0919631	WC0572419	WC0449634
	Sample Date		Client Info		10 Apr 2024	23 Apr 2021	31 Mar 2020
	Machine Age	hrs	Client Info		0	0	80
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Iron	ppm	ASTM D5185(m)	~15	0	<1	1
All metal levels are normal indicating no corrosion in the cooling	Aluminum	ppm	ASTM D5185(m)		<1	<1	<1
system.	Copper	ppm		>10	<1	<1	<1
	Lead	ppm	ASTM D5185(m)		0	<1	<1
	Tin	ppm	ASTM D5185(m)		0	<1	3
	Silver	ppm	ASTM D5185(m)	>10	<1	0	<1
	Zinc	ppm	ASTM D5185(m)	>10	1	2	2
CONTAMINANTS	Calcium	ppm	ASTM D5185(m)	>100	2	8	2
There is no indication of any contamination in the coolant.	Magnesium	ppm	ASTM D5185(m)	>40	<1	2	1
	Appearance	scalar	Visual*	NORML	NORML	NORML	NORM
	Odor	scalar	Visual*	NORML	NORML	NORML	NORM
	Coolant Appearance		Visual*	Clear		Clear	Clear
COOLANT CONDITION	Boiling Point	°C	WC Method*		108		
The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.	Specific Gravity		ASTM D1298*		1.072	1.067	1.066
	рН	Scale 0-14	ASTM D1287*		7.44	7.69	7.55
	Nitrites	ppm	Alcan Test Kit*		760	760	800
	Reserve Alkalinity	Scale 0-20	ASTM D1121*		5.8	5.2	5.6
	Percentage Glycol	%	ASTM D3321*		53.9	50.0	49.0
	Freezing Point	°C	ASTM D3321*		-42	-36	-35
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		30	22	21
	Phosphorus	ppm	ASTM D5185(m)		55	45	82
	Boron	ppm	ASTM D5185(m)		780	849	953
	Molybdenum	ppm	ASTM D5185(m)		<1	4	3
	Sodium	ppm	ASTM D5185(m)		4749	3223	3555
	Potassium	ppm	ASTM D5185(m)		241	169	213
	Coolant Color		Visual*		(Orange	Yellow





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

: WC0919631 Lab Number : 02629053

Unique Number : 5762185

Received : 15 Apr 2024 **Tested** Diagnosed

: 17 Apr 2024 : 17 Apr 2024 - Kevin Marson

2800

2400

Test Package : COOL (Additional Tests: GlycolType) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

GENREP LTD

476 HWY 77, R.R. #3 LEAMINGTON, ON CA N8H 3V6 Contact: Debbie Johnston djohnston@genrep.com T: (519)325-0202

F: (519)322-0026