CORROSION
CONTAMINANTS
COOLANT CONDITION

NORMAL NORMAL NORMAL

Machina Id C/O CBC ST JOHNS [6100286667]


16301004230


Component Coolant

Fluid

EXTENDED LIFE COOLANT (--- GAL)

EXTENDED LIFE COOLANT (GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service. Resample at the next service interval to monitor.	Sample Number		Client Info		WA0020881	WA0015057	WA
	Sample Date		Client Info		23 Apr 2024	27 Apr 2023	20 Aug 201
	Machine Age	hrs	Client Info		137	120	45
	Oil Age	hrs	Client Info		19	0	0
	Oil Changed		Client Info		Changed	N/A	Changed
	Sample Status				NORMAL	NORMAL	ABNORMA
CORROSION	Iron	ppm	ASTM D5185(m)	>15	0	1	<1
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D5185(m)	>10	2	2	2
	Copper	ppm	ASTM D5185(m)	>10	<1	2	<1
	Lead	ppm	ASTM D5185(m)	>10	0	<1	<1
	Tin	ppm	ASTM D5185(m)	>10	0	<1	<1
	Silver	ppm	ASTM D5185(m)	>10	<1	<1	1
	Zinc	ppm	ASTM D5185(m)	>10	5	5	0
CONTAMINANTS	Calcium	ppm	ASTM D5185(m)	>100	15	14	5
There is no indication of any contamination in the coolant.	Magnesium	ppm	ASTM D5185(m)	>40	7	8	5
	Appearance	scalar	Visual*	NORML	NORML	NORML	NORMI
	Odor	scalar	Visual*	NORML	NORML	NORML	NORMI
	Coolant Appearance		Visual*	Clear	Clear	Clear	Clear
COOLANT CONDITION The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.	Boiling Point	°C	WC Method*		108		
	Specific Gravity		ASTM D1298*		1.074	1.074	1.072
	рН	Scale 0-14	ASTM D1287*	9.0	7.89	7.83	7.91
	Nitrites	ppm	Alcan Test Kit*		640	560	480
	Reserve Alkalinity	Scale 0-20	ASTM D1121*		3.5	1.8	<u>1.5</u>
	Percentage Glycol		ASTM D3321*	50	55.5	55.3	54.0
	Freezing Point	°C	ASTM D3321*	-40	-44	-47	-44
	Carboxylate						
	Silicon	ppm	ASTM D5185(m)		12	14	9
	Phosphorus	ppm	ASTM D5185(m)		6	4	2
	Boron	ppm	ASTM D5185(m)		23	15	33
	Molybdenum	ppm	ASTM D5185(m)		165	202	225
	Sodium	ppm	ASTM D5185(m)		5244	3248	3217
	Potassium	ppm	ASTM D5185(m)	0	4903	3011	4097
	Coolant Color		Visual*	Orange/R	Orange	Orange	Red





: 25 Apr 2024

: 25 Apr 2024

: 26 Apr 2024 - Kevin Marson



CALA ISO 17025:2017 Accredited Laboratory

Sample No.

Laboratory

Lab Number : 02631409 Unique Number : 5772562

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : WA0020881 **Tested**

Diagnosed

Test Package : COOL (Additional Tests: GlycolType) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

WAJAX POWER SYSTEMS

1 PANTHER PLACE MOUNT PEARL, NL **CA A1N 5B7**

Contact: Alex Jr Earle aearle@wajax.com T: (709)747-7341

F: (709)747-8752