B POWER Station*

OIL ANALYSIS REPORT

[85521] 725 COLBOURNE ST, LONDON BELL CANADA BELL CANADA

Right Diesel Engine

Area

ESSO XD-3 EXTRA SAE 40 (60 LTR)

RECOMMENDATION

We advise that you check the fuel injection system. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

WEAR	

All component wear rates are normal.

CONTAMINATION

FLUID CONDITION

There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

Fuel is present in the oil and is lowering the viscosity. The oil is no


longer serviceable due to the presence of contaminants.


.....


	Test	UOM	Method	Limit/Abn	Current	History1	History2
	Sample Number		Client Info		PN0005976	PN0004492	PN0003366
	Sample Date		Client Info		22 Apr 2024	14 Feb 2023	22 Mar 2022
	Machine Age	hrs	Client Info		1158	1141	1113
	Oil Age	hrs	Client Info		0	0	30
	Filter Age	hrs	Client Info		0	0	30
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				SEVERE	SEVERE	SEVERE
	Iran				 0	0	0
	Iron	ppm	ASTM D5185(m)	>200	2 0	2	2
	Chromium	ppm	ASTM D5185(m)	>20	-	0	0
	Nickel	ppm	ASTM D5185(m)	>2	0	0	<1
	Titanium	ppm	ASTM D5185(m)	>2	0	0	0
	Silver	ppm	ASTM D5185(m)	>2	0	0	0
	Aluminum	ppm	ASTM D5185(m)	>30	0	<1	<1
	Lead	ppm	ASTM D5185(m)	>30	0	<1	<1
	Copper	ppm	ASTM D5185(m)	>30	4	3	4
	Tin	ppm	ASTM D5185(m)	>15	<1	<1	<1
	Vanadium	ppm	ASTM D5185(m)		0	0	0
	Silicon	ppm	ASTM D5185(m)	>30	3	3	4
	Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1
	Fuel	%	ASTM D7593*	>3.0	4 0.1	1 8.8	1 2
	Water		WC Method	>0.2	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	4.4	4.5	4.2
	Sulfation	Abs/.1mm	ASTM D7415*	>30	12.4	14.8	14.7
	Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
	Sodium	ppm	ASTM D5185(m)		6	7	22
	Boron	ppm	ASTM D5185(m)		6	11	10
	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		5	10	8
	Manganese	ppm	ASTM D5185(m)		0	<1	0
	Magnesium	ppm	ASTM D5185(m)		248	53	64
	Calcium	ppm	ASTM D5185(m)	2550	1708	2794	3004
	Phosphorus	ppm	ASTM D5185(m)	1000	556	614	686
	Zinc	ppm	ASTM D5185(m)	1120	613	616	714
	Sulfur	ppm	ASTM D5185(m)		1636	1951	2109
	Oxidation	Abs/.1mm	ASTM D7414*	>25	5.1	5.4	5.3
	Visc @ 100°C	cSt	ASTM D7279(m)	14.3	▲ 5.1	7 .3	9 .2

Report Id: POWMIS [WCAMIS] 02631483 (Generated: 04/29/2024 10:29:09) Rev: 1

Contact/Location: Brett Kinkley - POWMIS







Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PN0005976 Received : 26 Apr 2024 Lab Number : 02631483 Tested : 29 Apr 2024 ISO 17025:2017 Accredited : 29 Apr 2024 - Kevin Marson Unique Number : 5772636 Diagnosed Laboratory Test Package : MOB 1 (Additional Tests: PercentFuel) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T: F: (905)565-8544

Report Id: POWMIS [WCAMIS] 02631483 (Generated: 04/29/2024 10:29:13) Rev: 1

Contact/Location: Brett Kinkley - POWMIS Page 2 of 2