# POWER GENERATION PRODUCTS

OIL ANALYSIS REPORT

WEAR NORMAL CONTAMINATION SEVERE FLUID CONDITION ABNORMAL

## [85313] 2222 EGLINTON AVE E TORONTO CITY OF TORONTO RG6125H037656

### **Right Diesel Engine**

ESSO XD-3 EXTRA 15W40 (40 LTR)

#### RECOMMENDATION

-----

We advise that you check the fuel injection system. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

vv	A 1	<b>I H</b>

Area

Metal levels are typical for a new component breaking in.

# CONTAMINATION

There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

	Test	UOM	Method	Limit/Abn	Current	History1	History2
he oil change at	Sample Number		Client Info		PN0006107	PN0004660	PN0002425
an early	Sample Date		Client Info		23 Apr 2024	28 Apr 2023	29 Apr 2021
	Machine Age	hrs	Client Info		299	290	258
	Oil Age	hrs	Client Info		10	0	0
	Filter Age	hrs	Client Info		10	0	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				SEVERE	SEVERE	SEVERE
	Iron	ppm	ASTM D5185(m)	>51	<1	1	2
in.	Chromium	ppm	ASTM D5185(m)	>	0	0	0
	Titonium	ppm		>0	0	<1	0
	Silver	ppm		. 2	0	0	0
	Aluminum	ppm		>0	-1	0	0
	Aluminum	ppm		>31	<1	2	2
	Coppor	ppm		>20	-1	<1	< 1
	Copper	ppm		>20	<1	<1	<
	Manadium	ppm	ASTM D5105(III)	>4	0	<1	<1
	vanadium		A21M D2102(III)		U	0	< 1
	Silicon	ppm	ASTM D5185(m)	>22	4	11	6
confirm the	Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1
	Fuel	%	ASTM D7593*	>2.1	<b>1</b> 0	<b>1</b> 0.3	<b>5</b> .9
	Water		WC Method	>0.21	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	4.6	6.0	6.6
	Sulfation	Abs/.1mm	ASTM D7415*	>30	17.8	18.0	18.8
	Emulsified Water	scalar	Visual*	>0.21	NEG	NEG	NEG
	Sodium	maa	ASTM D5185(m)	>192	<1	1	2
	Boron	ppm	ASTM D5185(m)		5	43	64
c is abnormally sity. The oil is no ts.	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		54	63	66
	Manganese	ppm	ASTM D5185(m)		0	<1	<1
	Magnesium	ppm	ASTM D5185(m)		846	392	153
	Calcium	ppm	ASTM D5185(m)	3780	<b>4</b> 989	1616	1860
	Phosphorus	ppm	ASTM D5185(m)	1370	916	977	874
	Zinc	ppm	ASTM D5185(m)	1500	1060	1005	1033
	Sulfur	ppm	ASTM D5185(m)	3800	2410	2674	2897
	Oxidation	Abs/.1mm	ASTM D7414*	>25	13.3	14.1	14.6
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<b>11.3</b>	▲ 10.2	▲ 11.5
			. /				

#### FLUID CONDITION

-----

Calcium ppm levels are abnormally low. Visc @ 100°C is abnormally low. Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

Contact/Location: Brett Kinkley - POWMIS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PN0006107 Received : 26 Apr 2024 Lab Number : 02631495 Tested : 29 Apr 2024 ISO 17025:2017 Accredited Laboratory : 29 Apr 2024 - Wes Davis Unique Number : 5772648 Diagnosed Test Package : MOB 1 (Additional Tests: PercentFuel) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T: F: (905)565-8544

Contact/Location: Brett Kinkley - POWMIS Page 2 of 2