



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Machine Id  
**19 MAIN ST TORONTO BELL CANADA 348906-1-10812**  
 Component  
**Front Diesel Engine**  
 Fluid  
**ESSO XD-3 EXTRA 15W40 (60 LTR)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>PN0006091</b>	PN0004626	PN0003440
Sample Date		Client Info		<b>18 Apr 2024</b>	28 Mar 2023	31 Mar 2022
Machine Age	hrs	Client Info		<b>283</b>	244	220
Oil Age	hrs	Client Info		<b>0</b>	0	36
Filter Age	hrs	Client Info		<b>0</b>	0	36
Oil Changed		Client Info		<b>Changed</b>	Not Chngd	Changed
Filter Changed		Client Info		<b>Changed</b>	Not Chngd	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>100	<b>&lt;1</b>	1	1
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>4	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Silver	ppm	ASTM D5185(m)	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>2</b>	4	3
Lead	ppm	ASTM D5185(m)	>40	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>330	<b>&lt;1</b>	2	7
Tin	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0

**CONTAMINATION**











There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	<b>1</b>	3	6
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	1
Fuel		WC Method	>5	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	ASTM D7844*	>3	<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>4.7</b>	7.3	7.5
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>17.6</b>	20.5	19.4
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	<b>1</b>	3	3
Boron	ppm	ASTM D5185(m)		<b>11</b>	75	74
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>62</b>	86	80
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)		<b>841</b>	42	88
Calcium	ppm	ASTM D5185(m)	3780	<b>1202</b>	2281	2109
Phosphorus	ppm	ASTM D5185(m)	1370	<b>1020</b>	1120	1074
Zinc	ppm	ASTM D5185(m)	1500	<b>1174</b>	1171	1162
Sulfur	ppm	ASTM D5185(m)	3800	<b>2706</b>	3356	3232
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>12.7</b>	12.7	14.3
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<b>14.6</b>	14.1	14.4



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PN0006091  
**Lab Number** : 02631523  
**Unique Number** : 5772676  
**Test Package** : MOB 1  
**Received** : 26 Apr 2024  
**Tested** : 26 Apr 2024  
**Diagnosed** : 26 Apr 2024 - Wes Davis

**POWER STATION INC.**  
 1050 JAYSON COURT  
 MISSISSAUGA, ON  
 CA L4W 2V5  
 Contact: Brett Kinkley  
 Bkinkley@pwrstn.com  
 T:  
 F: (905)665-8544

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.