WEAR CONTAMINATION FLUID CONDITION


NORMAL MARGINAL ABNORMAL

Machine Id

125 MANITOBA ST BRACEBRIDGE BELL CANADA LOC#331341

Right Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History	Hietory?
	Sample Number	UUIVI	Client Info	LIIIII/ADN	PN0006031	History1 PN0004398	History2 PN0002935
The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.	Sample Number		Client Info		19 Apr 2024	03 Jan 2023	11 Nov 2021
	Machine Age	hrs	Client Info		626	602	186
	Oil Age	hrs	Client Info		23	0	16
	Filter Age	hrs	Client Info		23	0	16
	Oil Changed	0	Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				ABNORMAL	NORMAL	NORMAL
147-1-1							
WEAR	Iron	ppm	ASTM D5185(m)	>120	5	3	5
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)		0	0	<1
	Nickel	ppm	ASTM D5185(m)		0	0	<1
	Titanium	ppm	ASTM D5185(m)		0	0	0
	Silver	ppm	ASTM D5185(m)		0	0	0
	Aluminum	ppm	ASTM D5185(m)		<1	<1	2
	Lead	ppm	ASTM D5185(m)		1	1	<1
	Copper	ppm	ASTM D5185(m)		2	1	1
	Tin	ppm	ASTM D5185(m)	>15	1	<1	<1
	Vanadium	ppm	ASTM D5185(m)		0 	0	<1
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	3	3	4
Light fuel dilution occurring.	Potassium	ppm	ASTM D5185(m)	>20	<1	0	1
	Fuel	%	ASTM D7593*	>3.0	1.7	1.5	<1.0
	Water		WC Method	>0.2	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>0.8	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	3.7	3.6	8.0
	Sulfation	Abs/.1mm	ASTM D7415*	>30	13.4	14.0	19.4
	Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Phosphorus ppm levels are abnormally low. Zinc ppm levels are abnormally low. Visc @ 100°C is abnormally low. Fuel is present in the oil and is lowering the viscosity.	Sodium	ppm	ASTM D5185(m)	>192	5	4	2
	Boron	ppm	ASTM D5185(m)		17	9	73
	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		7	8	83
	Manganese	ppm	ASTM D5185(m)		0	<1	<1
	Magnesium	ppm	ASTM D5185(m)		23	23	66
	Calcium	ppm	ASTM D5185(m)	3780	3475	3877	2135
	Phosphorus	ppm	ASTM D5185(m)	1370	△ 694	745	1077
	Zinc	ppm	ASTM D5185(m)	1500	4 760	764	1195
	Sulfur	ppm	ASTM D5185(m)	3800	2414	2510	3366
	Oxidation	Abs/.1mm	ASTM D7414*	>25	4.8	4.8	13.6
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<u></u> 12.4	12.7	13.5





CALA
Ture
Acceptable 19991

ISO 17025:2017
Accredited

 Laboratory
 : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

 Sample No.
 : PN0006031
 Received
 : 26 Apr 2024

 Lab Number
 : 02631528
 Tested
 : 29 Apr 2024

Accredited Laboratory Unique Number : 5772681 Diagnosed : 29 Apr 2024 - Wes Davis Test Package : MOB 1 (Additional Tests: FUELDILUTION, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T:

F: (905)565-8544

. (000)000 00