



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
SOBEYS VAUGHAN [4501238207]
 Machine Id
FRICK COMP #1 (S/N 10241E53800311)
 Component
1 Screw Compressor
 Fluid
FRICK COMPRESSOR OIL #3 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0902702	WC0749622	---
Sample Date		Client Info		27 Mar 2024	08 Nov 2022	---
Machine Age	hrs	Client Info		0	17480	---
Oil Age	hrs	Client Info		22674	7000	---
Filter Age	hrs	Client Info		0	7000	---
Oil Changed		Client Info		N/A	Not Changd	---
Filter Changed		Client Info		N/A	Not Changd	---
Sample Status				NORMAL	NORMAL	---

WEAR

All component wear rates are normal.

PQ		ASTM D8184*		0	0	---
Iron	ppm	ASTM D5185(m)	>60	1	1	---
Chromium	ppm	ASTM D5185(m)	>4	0	0	---
Nickel	ppm	ASTM D5185(m)		0	<1	---
Titanium	ppm	ASTM D5185(m)		0	0	---
Silver	ppm	ASTM D5185(m)		0	0	---
Aluminum	ppm	ASTM D5185(m)	>5	0	<1	---
Lead	ppm	ASTM D5185(m)	>10	0	0	---
Copper	ppm	ASTM D5185(m)	>30	0	<1	---
Tin	ppm	ASTM D5185(m)	>15	0	0	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---

CONTAMINATION










The water content is negligible. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>50	0	0	---
Potassium	ppm	ASTM D5185(m)	>20	<1	0	---
Water	%	ASTM D6304*	>0.1	0.001	0.001	---
ppm Water	ppm	ASTM D6304*	>1000	2	6.8	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	---

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185(m)		0	0	---
Boron	ppm	ASTM D5185(m)		0	0	---
Barium	ppm	ASTM D5185(m)		2	4	---
Molybdenum	ppm	ASTM D5185(m)		0	0	---
Manganese	ppm	ASTM D5185(m)		0	0	---
Magnesium	ppm	ASTM D5185(m)		<1	0	---
Calcium	ppm	ASTM D5185(m)		0	0	---
Phosphorus	ppm	ASTM D5185(m)		0	0	---
Zinc	ppm	ASTM D5185(m)		<1	1	---
Sulfur	ppm	ASTM D5185(m)		17	18	---
Acid Number (AN)	mg KOH/g	ASTM D974*		0.02	0.02	---
Visc @ 40°C	cSt	ASTM D7279(m)	73	69.5	68.3	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0902702 **Received** : 29 Apr 2024
Lab Number : 02631977 **Tested** : 01 May 2024
Unique Number : 5773130 **Diagnosed** : 01 May 2024 - Wes Davis
Test Package : IND 2 (Additional Tests: KF, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

CIMCO Refrigeration
 1551 Corporate Drive
 Burlington, ON
 CA L7L 6M3
 Contact: DAVID PARISE
 DPARISE@ToROMONT.COM
 T: (416)465-7581
 F: (416)465-8815