



WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
1368 EFFINGHAM PELHAM BELL CANADA 95-12736
 Component
Left Diesel Engine
 Fluid
ESSO XD-3 EXTRA 15W40 (10 LTR)

RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0006140	PN0002050	PN0000894
Sample Date		Client Info		26 Apr 2024	08 Mar 2021	20 Mar 2020
Machine Age	hrs	Client Info		30	151	161
Oil Age	hrs	Client Info		0	0	19
Filter Age	hrs	Client Info		0	0	19
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>250	2	2	4
Chromium	ppm	ASTM D5185(m)	>10	0	0	<1
Nickel	ppm	ASTM D5185(m)	>5	0	<1	0
Titanium	ppm	ASTM D5185(m)		0	<1	<1
Silver	ppm	ASTM D5185(m)	>3	0	0	0
Aluminum	ppm	ASTM D5185(m)	>35	2	2	1
Lead	ppm	ASTM D5185(m)	>100	<1	0	3
Copper	ppm	ASTM D5185(m)	>60	2	<1	1
Tin	ppm	ASTM D5185(m)	>5	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	<1	0
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---

CONTAMINATION












Fuel content negligible. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>35	5	10	5
Potassium	ppm	ASTM D5185(m)	>20	1	<1	<1
Fuel	%	ASTM D7593*	>5	0.7	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	5.1	6.6	6.1
Sulfation	Abs/.1mm	ASTM D7415*	>30	14.6	18.0	23.8
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	VLITE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG

FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	2	4	5
Boron	ppm	ASTM D5185(m)		43	65	41
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		43	71	44
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)		63	157	624
Calcium	ppm	ASTM D5185(m)	3780	2207	1952	1527
Phosphorus	ppm	ASTM D5185(m)	1370	981	919	867
Zinc	ppm	ASTM D5185(m)	1500	1090	1114	995
Sulfur	ppm	ASTM D5185(m)	3800	2733	3173	2441
Oxidation	Abs/.1mm	ASTM D7414*	>25	9.5	13.7	17.5
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	12.7	13.9	13.2



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PN0006140
Lab Number : 02632496
Unique Number : 5773649
Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel, Visual)

Received : 01 May 2024
Tested : 02 May 2024
Diagnosed : 02 May 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.
 1050 JAYSON COURT
 MISSISSAUGA, ON
 CA L4W 2V5
 Contact: Ryan Udall
 rudall@pwrstn.com
 T: (905)565-1621
 F: (905)629-1499