

WEAR NORMAL CONTAMINATION ABNORMAL FLUID CONDITION SEVERE

Machine Id QC230725MOB2 Component Diesel Engine Fluid DIESEL ENGINE OIL SAE 40 (--- GAL)

RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please specify the component make and model with your next sample.

WEAR

All component wear rates are normal.

CONTAMINATION

Light fuel dilution occurring. There is a light concentration of water present in the oil. No other contaminants were detected in the oil.

FLUID CONDITION

The low BN value indicates relatively little reserve alkalinity remaining in this oil. Viscosity of sample indicates oil is within SAE 10W30 range, advise investigate. The oil is no longer serviceable.

Test	UOM	Method	Limit/Abn	Current	Hi	story1	Hi	story2
Sample Number		Client Info		WC093654	4 W	C0936543	W	C0936542
Sample Date		Client Info		03 May 202	4 02	May 2024	01	May 2024
Machine Age	hrs	Client Info		0	0		0	
Oil Age	hrs	Client Info		0	0		0	
Filter Age	hrs	Client Info		0	0		0	
Oil Changed		Client Info		N/A	N/	/A	N/A	
Filter Changed		Client Info		N/A	N	/A	N/A	
Sample Status				SEVERE	AE	BNORMAL	ABNORMAL	
Iron	ppm	ASTM D5185(m)	>100	20		19		19
Chromium	ppm	ASTM D5185(m)	>20	<1		<1		<1
Nickel	ppm	ASTM D5185(m)	>4	<1		0		0
Titanium	ppm	ASTM D5185(m)		3		3		3
Silver	ppm	ASTM D5185(m)	>3	0		0		0
Aluminum	ppm	ASTM D5185(m)	>20	4		4		4
Lead	ppm	ASTM D5185(m)	>40	2		1		<1
Copper	ppm	ASTM D5185(m)	>330	9		9		9
Tin	ppm	ASTM D5185(m)	>15	0		0		0
Vanadium	ppm	ASTM D5185(m)		0		0		0
Silicon	ppm	ASTM D5185(m)	>25	6		5		5
Potassium	ppm	ASTM D5185(m)	>20	▲ 15		51		14
Fuel	%	ASTM D7593*	>5	4.9		4.8		4.9
Water	%	ASTM D6304*	>0.2	▲ 0.203				0.186
ppm Water	ppm	ASTM D6304*	>2000	▲ 2035		2061		1863
Glycol	%	ASTM D7922*	- 2000	NEG		0.0		NEG
Soot %	%	ASTM D7844*	>3	0.3		0.3		0.3
Nitration	Abs/cm	ASTM D7624*	>20	9.9		9.9		9.9
Sulfation	Abs/.1mm	ASTM D7415*	>30	20.7		20.8		20.8
Emulsified Water	scalar	Visual*	>0.2	<u>^</u> .2%		.2%		.2%
Sodium	ppm	ASTM D5185(m)	>216	64		71		61
Boron	ppm	ASTM D5185(m)	250	32		33		32
Barium	ppm	ASTM D5185(m)	10	<1		<1		<1
Molybdenum	ppm	ASTM D5185(m)	100	48		47		47
Manganese	ppm	ASTM D5185(m)		<1		<1		<1
Magnesium	ppm	ASTM D5185(m)	450	633		606		619
Calcium	ppm	ASTM D5185(m)	3000	1487		1434		1450
Phosphorus	ppm	ASTM D5185(m)	1150	861		842		851
Zinc	ppm	ASTM D5185(m)	1350	1014		973		1005
Sulfur	ppm	ASTM D5185(m)	4250	2577		2519		2575
Oxidation	Abs/.1mm	ASTM D7414*	>25	16.2		16.2		16.1
Base Number (BN)	mg KOH/g	ASTM D2896*	8.5	A 0.536		8.73		9.21
Visc @ 40°C	cSt	ASTM D7279(m)	138	A 75.2		75.2		75.1
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	🔺 11.3		11.4		11.4
Viscosity Index (VI)	Scale	ASTM D2270*	102	141	J	143		143



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 WearCheck Quality Control Sample Results CALA Sample No. : WC0936544 Received :03 May 2024 Lab Number :06 May 2024 : 02632990 Tested Burlington, ON ISO 17025:2017 : 06 May 2024 - Kevin Marson Accredited Unique Number : 5774143 Diagnosed CA Laboratory Test Package : MOB 2 (Additional Tests: FuelDilution, Glycol, KF, KV40, PercentFuel, VI) Contact: Dorian Anderson dorian.anderson@wearcheck.com To discuss this sample report, contact Customer Service at 1-800-268-2131. T: (289)291-4652 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (905)569-8605 Validity of results and interpretation are based on the sample and information as supplied.