MOB

WEAR CHECK

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	ABNORMAL

Machine Id
1 PALACE PIER
Component
Diesel Engine
Fluid
PETRO CANADA XR 4 SAE 15W40 (--- LTR)

RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Please specify the component make and model with your next sample.

WEAR

All component wear rates are normal.

CONTAMINATION

There is a moderate amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

FLUID CONDITION

Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0910640	WC0794978	WC0727146
Sample Date		Client Info		02 Apr 2024	04 Jun 2023	04 Sep 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185(m)	>100	6	5	6
Chromium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Nickel	ppm	ASTM D5185(m)	>4	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	<1	<1
Silver	ppm	ASTM D5185(m)	>3	0	▲ 3	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>40	3	2	3
Copper	ppm	ASTM D5185(m)	>330	2	2	3
Tin	ppm	ASTM D5185(m)	>15	2	1	2
Vanadium	ppm	ASTM D5185(m)		0	0	0
Silicon	ppm	ASTM D5185(m)	>25	12	10	17
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Fuel	%	ASTM D7593*	>5	▲ 5.5	▲ 5.1	▲ 5.1
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	4.5	4.5	5.0
Sulfation	Abs/.1mm	ASTM D7415*	>30	18.1	18.2	19.7
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Sodium	ppm	ASTM D5185(m)		1	1	2
Boron	ppm	ASTM D5185(m)	1	4	13	<1
Barium	ppm	ASTM D5185(m)	1	0	0	0
Molybdenum	ppm	ASTM D5185(m)	1	57	59	56
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)	10	953	898	927
Calcium	ppm	ASTM D5185(m)	3032	1001	1031	1058
Phosphorus	ppm	ASTM D5185(m)	1054	985	1010	1077
Zinc	ppm	ASTM D5185(m)	1332	1136	1078	1161
Sulfur	ppm	ASTM D5185(m)	3985	2641	2577	2826
Oxidation	Abs/.1mm	ASTM D7414*	>25	13.3	13.2	13.9
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	▲ 11.3	▲ 12.1	▲ 11.6

Fuel Dilution



Viscosity @ 100°C



FT-IR (Direct Trend)



Iron (ppm)



Lead (ppm)



Aluminum (ppm)



Chromium (ppm)



Copper (ppm)



Silicon (ppm)



Viscosity @ 100°C



Fuel Dilution



ISO 17025:2017 Accredited Laboratory

Laboratory	: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9		
Sample No.	: WC0910640	**Received**	: 03 May 2024
Lab Number	: 02632998	**Tested**	: 06 May 2024
Unique Number	: 5774151	**Diagnosed**	: 06 May 2024 - Wes Davis
Test Package	: MOB 1 (Additional Tests: PercentFuel)		

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

NORTHERN GENERATOR CO. LTD.
80 ASHBRIDGE CIRCLE,, UNIT #1 & 2
WOODBRIDGE, ON
CA L4L 3R5
Contact: Selome Afework
selome@northerngenerator.com
T: (905)264-9744
F: (905)264-9714