WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL ABNORMAL

Machine Id

11 RUDDINGTON

Diesel Fnaine

| RECOMMENDATION | Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|--|-------------------------|----------|-------------------------------|-----------------|-------------|-------------|-------------|
| Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. Please specify the component make and model with your next sample. | Sample Number | | Client Info | | WC0914909 | WC0810815 | WC0678628 |
| | Sample Date | | Client Info | | 29 Apr 2024 | 03 May 2023 | 19 May 2022 |
| | Machine Age | yrs | Client Info | | 0 | 0 | 0 |
| | Oil Age | yrs | Client Info | | 0 | 0 | 0 |
| | Filter Age | yrs | Client Info | | 0 | 0 | 0 |
| | Oil Changed | | Client Info | | N/A | N/A | N/A |
| | Filter Changed | | Client Info | | N/A | N/A | N/A |
| | Sample Status | | | | ABNORMAL | ABNORMAL | NORMAL |
| WEAR | Iron | ppm | ASTM D5185(m) | >100 | 12 | 10 | 8 |
| WEAIT | Chromium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| All component wear rates are normal. | Nickel | ppm | ASTM D5185(m) | | 0 | <1 | 0 |
| | Titanium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| | Silver | ppm | ASTM D5185(m) | >3 | 0 | 0 | 0 |
| | Aluminum | ppm | ASTM D5185(m) | | 2 | 1 | 2 |
| | Lead | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | Copper | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| | Tin | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | White Metal | scalar | Visual* | NONE | NONE | | |
| | Yellow Metal | scalar | Visual* | NONE | NONE | | |
| CONTAMINATION | Silicon | nnm | ASTM D5185(m) | . 25 | Л | 6 | 6 |
| CONTAMINATION | Potassium | ppm | ASTM D5185(m) | | 4 19 | <1 | <1 |
| Tests indicate that there is no fuel present in the oil. There is no indication of any contamination in the oil. | Fuel | ppm % | ASTM D3163(III) ASTM D7593* | | 0.0 | 0.4 | <1.0 |
| | Water | /0 | WC Method | | NEG | NEG | NEG |
| | Glycol | % | ASTM D7922* | <i>></i> 0.2 | 0.0 | NEG | NEG |
| | Soot % | % | ASTM D7844* | \3 | 0.0 | 0 | 0 |
| | Nitration | Abs/cm | ASTM D7624* | | 4.9 | 6.3 | 6.6 |
| | Sulfation | Abs/.1mm | ASTM D7415* | | 14.4 | 15.3 | 17.4 |
| | Silt | scalar | Visual* | NONE | NONE | | |
| | Debris | scalar | Visual* | NONE | NONE | | |
| | Sand/Dirt | scalar | Visual* | NONE | VLITE | | |
| | Appearance | scalar | Visual* | NORML | NORML | | |
| | Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| | Emulsified Water | | Visual* | >0.2 | NEG | NEG | NEG |
| FLUID CONDITION | Sodium | nnm | ASTM D5185(m) | | 5 | 2 | 2 |
| Viscosity of sample indicates oil is within SAE 30 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The condition of the oil is acceptable for the time in service. | Boron | ppm | ASTM D5185(III) ASTM D5185(m) | 1 | 5 68 | 33 | 68 |
| | Barium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | Molybdenum | ppm | ASTM D5185(m) | | 134 | 58 | 58 |
| | Manganese | ppm | ASTM D5185(m) | - | <1 | <1 | <1 |
| | Magnesium | ppm | ASTM D5185(m) | 10 | 436 | 384 | 660 |
| | Calcium | ppm | ASTM D5185(m) | | 1176 | 999 | 1000 |
| | | | . / | | | • | |

Zinc

Sulfur

Oxidation

ppm

Visc @ 100°C cSt ASTM D7279(m) 15.4

ASTM D5185(m) 1332

ppm ASTM D5185(m) 3985

584

1494

8.3

9.9

687

7.8

9.9


1490

693

12.4

10.4

1700





CALA ISO 17025:2017 Accredited Laboratory

Unique Number : 5774183

Laboratory Sample No. Lab Number

: WC0914909 : 02633030

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received **Tested**

: 03 May 2024 : 07 May 2024 Diagnosed

: 07 May 2024 - Kevin Marson

NORTHERN GENERATOR CO. LTD. 80 ASHBRIDGE CIRCLE,, UNIT #1 & 2

WOODBRIDGE, ON CA L4L 3R5 Contact: Selome Afework

Test Package : MOB 1 (Additional Tests: FUELDILUTION, Glycol, PercentFuel, Visual) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

selome@northerngenerator.com T: (905)264-9744

F: (905)264-9714